

## Chapter9\_example2

The LMTD for counter flow configuration is 72.1 degree C

For a finite heat-transfer rate and a finite overall heat-transfer coefficient,  
if parallel flow is to give equal outlet temperatures,  
then the area needed must be infinite which is not feasible economically.