

Scilab Textbook Companion for
Electrical Power Systems
by C. L. Wadhwa¹

Created by
Anuj Bansal
B.E
Electrical Engineering
Thapar University, Patiala(Punjab)
College Teacher
Dr. Sunil Kumar Singla
Cross-Checked by
Lavitha Pereira

July 13, 2017

¹Funded by a grant from the National Mission on Education through ICT,
<http://spoken-tutorial.org/NMEICT-Intro>. This Textbook Companion and Scilab
codes written in it can be downloaded from the "Textbook Companion Project"
section at the website <http://scilab.in>

Book Description

Title: Electrical Power Systems

Author: C. L. Wadhwa

Publisher: New Age International Pvt. Ltd., New Delhi

Edition: 6

Year: 2010

ISBN: 9788122428391

Scilab numbering policy used in this document and the relation to the above book.

Exa Example (Solved example)

Eqn Equation (Particular equation of the above book)

AP Appendix to Example(Scilab Code that is an Appednix to a particular Example of the above book)

For example, Exa 3.51 means solved example 3.51 of this book. Sec 2.3 means a scilab code whose theory is explained in Section 2.3 of the book.

Contents

List of Scilab Codes	4
1 FUNDAMENTALS OF POWER SYSTEMS	5
2 LINE CONSTANT CALCULATIONS	7
3 CAPACITANCE OF TRANSMISSION LINES	12
4 PERFORMANCE OF LINES	14
5 HIGH VOLTAGE DC TRANSMISSION	25
6 CORONA	28
7 MECHANICAL DESIGN OF TRANSMISSION LINES	32
8 OVERHEAD LINE INSULATORs	36
9 INSULATED CABLES	37
10 VOLTAGE CONTROL	43
11 NEUTRAL GROUNDING	47
12 TRANSIENTS IN POWER SYSTEMS	49
13 SYMMETRICAL COMPONENTS AND FAULT CALCULATIONS	54
14 PROTECTIVE RELAYS	69

15 CIRCUIT BREAKERS	76
17 POWER SYSTEM SYNCHRONOUS STABILITY	80
18 LOAD FLOWS	90
19 ECONOMIC LOAD DISPATCH	97
20 LOAD FREQUENCY CONTROL	100
21 COMPENSATION IN POWER SYSTEMS	102
22 POWER SYSTEM VOLTAGE STABILITY	104
23 STATE ESTIMATION IN POWER SYSTEMS	108
24 UNIT COMMITMENT	113
25 ECONOMIC SCHEDULING OF HYDROTHERMAL PLANTS AND OPTIMAL POWER FLOWS	116

List of Scilab Codes

Exa 1.1	To determine the Base values and pu values	5
Exa 2.2	To determine inductance of a 3 phase line	7
Exa 2.3	Determine the equivalent radius of bundle conductor having its part conductors r on the periphery of circle of dia d	7
Exa 2.4	To determine the inductance of single phase Transmission line	8
Exa 2.5	To determine the inductance per Km of 3 phase line .	9
Exa 2.6	To determine the inductance of double circuit line . .	10
Exa 2.7	To determine the inductance per Km per phase of single circuit	10
Exa 3.1	To determine the capacitance and charging current . .	12
Exa 3.2	To determine the capacitance and charging current . .	12
Exa 3.3	To determine the capacitance and charging current . .	13
Exa 4.1	To determine the sending end voltage and current power and power factor Evaluate A B C D parameters . . .	14
Exa 4.2	To determine power input and output i star connected ii delta connected	15
Exa 4.3	To determine efficiency and regulation of line	16
Exa 4.4	To calculate the voltage across each load impedance and current in the neutral	16
Exa 4.5	To determine efficiency and regulation of 3 phase line .	17
Exa 4.6	To find the rms value and phase values i The incident voltage to neutral at the receiving end ii The reflected voltage to neutral at the receiving end iii The incident and reflected voltage to neutral at 120 km from the receiving end	18
Exa 4.7	To determine of efficiency of line	20

Exa 4.8	To determine the ABCD parameters of Line	21
Exa 4.9	To determine the sending end voltage and efficiency using Nominal pi and Nominal T method	22
Exa 4.10	To determine the sending end voltage and current power and power factor Evaluate A B C D parameters	23
Exa 5.1	To determine the dc output voltage when delay anglw a0 b30 c45	25
Exa 5.2	To determine the necessary line secondary voltage and tap ratio required	25
Exa 5.3	To determine the effective reactance per phase	26
Exa 5.4	Calculate the direct current delivered	26
Exa 6.1	To determine the critical disruptive voltage and critical voltage for local and general corona	28
Exa 6.2	To determine whether corona will be present in the air space round the conductor	29
Exa 6.3	To determine the critical disruptive voltage and corona loss	29
Exa 6.4	To determine the voltage for which corona will commence on the line	30
Exa 6.5	To determine the corona characteristics	30
Exa 7.1	Calculate the sag	32
Exa 7.2	To calculate the maximum Sag	33
Exa 7.3	To determine the Sag	33
Exa 7.4	To determine the clearance between the conductor and water level	34
Exa 8.1	To determine the maximum voltage that the string of the suspension insulators can withstand	36
Exa 9.1	To determine the economic overall diameter of a 1core cable metal sheathhead	37
Exa 9.2	To determine the minimum internal diameter of the lead sheath	37
Exa 9.3	To determine the maximum safe working voltage	38
Exa 9.4	To determine the maximum stresses in each of the three layers	39
Exa 9.5	determine the equivalent star connected capacity and the kVA required	39

Exa 9.6	Determine the capacitance a between any two conductors b between any two bunched conductors and the third conductor c Also calculate the charging current per phase per km	40
Exa 9.7	To calculate the induced emf in each sheath	41
Exa 9.8	To determine the ratio of sheath loss to core loss of the cable	41
Exa 10.1	To determine the total power active and reactive supplied by the generator and the pf at which the generator must operate	43
Exa 10.2	Determine the settings of the tap changers required to maintain the voltage of load bus bar	44
Exa 10.3	i Find the sending end Voltage and the regulation of line ii Determine the reactance power supplied by the line and by synchronous capacitor and pf of line iii Determine the maximum power transmitted	44
Exa 10.4	Determine the KV Ar of the Modifer and the maximum load that can be transmitted	46
Exa 11.1	To find the inductance and KVA rating of the arc suppressor coil in the system	47
Exa 11.2	Determine the reactance to neutralize the capacitance of i 100 percent of the length of line ii 90 percent of the length of line iii 80 percent of the length of line	48
Exa 12.1	To determine the i the neutral impedance of line ii line current iii rate of energy absorption rate of reflection and state form of reflection iv terminating resistance v amount of reflected and transmitted power	49
Exa 12.2	Find the voltage rise at the junction due to surge . .	50
Exa 12.3	To find the surge voltages and currents transmitted into branch line	51
Exa 12.4	Determine the maximum value of transmitted wave . .	52
Exa 12.5	Determine the maximum value of transmitted surge . .	52
Exa 12.6	Determine i the value of the Voltage wave when it has travelled through a distance 50 Km ii Power loss and Heat loss	53
Exa 13.1	Determine the symmetrical components of voltages . .	54
Exa 13.2	Find the symmetrical component of currents	55
Exa 13.3	Determine the fault current and line to line voltages .	55

Exa 13.4	determine the fault current and line to line voltages at the fault	56
Exa 13.5	determine the fault current and line to line voltages at the fault	58
Exa 13.6	Determine the fault current when i LG ii LL iii LLG fault takes place at P	59
Exa 13.8	Determine the percent increase of busbar voltage	60
Exa 13.9	Determine the short circuit capacity of the breaker	60
Exa 13.10	To determine the short circuit capacity of each station	61
Exa 13.11	Determine the Fault MVA	61
Exa 13.12	To Determine the subtransient current in the alternator motor and the fault	62
Exa 13.13	To Determine the reactance of the reactor to prevent the breakers being overloaded	63
Exa 13.14	Determine the subtransient currents in all phases of machine1 the fault current and the voltages of machine 1 and voltage at the fault point	63
Exa 13.15	To determine the i pre fault current in line a ii the subtransient current in pu iii the subtransient current in each phase of generator in pu	65
Exa 13.16	Determine the shorrt circuit MVA of the transformer	66
Exa 13.17	To determine the line voltages and currents in per unit on delta side of the transformer	66
Exa 14.1	To determine the time of operation of relay	69
Exa 14.2	To determine the phase shifting network to be used	69
Exa 14.3	To provide time current grading	70
Exa 14.4	To determine the proportion of the winding which remains unprotected against earth fault	71
Exa 14.5	To determine i percent winding which remains unprotected ii min value of earthing resistance required to protect 80 percent of winding	71
Exa 14.6	To determine whether relay will operate or not	72
Exa 14.7	To determine the ratio of CT on HV side	72
Exa 14.8	To determine the number of turns each current transformer should have	73
Exa 14.9	To determine the R1 R2 and C also The potential across relays	73

Exa 14.10	To determine the kneepoint voltage and cross section of core	74
Exa 14.11	To determine the VA output of CT	75
Exa 15.1	To determine the voltage appearing across the pole of CB also determine the value of resistance to be used across contacts	76
Exa 15.2	To determine the rate of rise of restriking voltage	77
Exa 15.3	To Determine the average rate of rise of restriking voltage	77
Exa 15.4	To determine the rated normal current breaking current making current and short time rating current	78
Exa 15.5	TO Determine i sustained short circuit current in the breaker ii initial symmetrical rms current in the breaker iii maximum possible dc component of the short circuit current in the breaker iv momentary current rating of the breaker v the current	78
Exa 17.1	To determine the acceleration Also determine the change in torque angle and rmpat the end of 15 cycles	80
Exa 17.2	To determine the frequency of natural oscillations if the generator is loaded to i 60 Percent and ii 75 percent of its maximum power transfer capacity	81
Exa 17.3	To calculate the maximum value of d during the swinging of the rotor around its new equilibrium position	82
Exa 17.4	To calculate the critical clearing angle for the condition described	82
Exa 17.5	To calculate the critical clearing angle for the generator for a 3phase fault	83
Exa 17.6	determine the critical clearing angle	84
Exa 17.7	To determine the centre and radius for the pull out curve ans also minimum output vars when the output powers are i 0 ii 25pu iii 5pu	85
Exa 17.8	Compute the prefault faulted and post fault reduced Y matrices	86
Exa 17.9	Determine the reduced admittance matrices for prefault fault and post fault conditions and determine the power angle characterstics for three conditions	86
Exa 17.10	To Determine the rotor angle and angular frequency using runga kutta and eulers modified method	87

Exa 18.1	Determine the voltages at the end of first iteration using gauss seidal method	90
Exa 18.2	Determine the voltages starting with a flat voltage profile	91
Exa 18.3	Solve the previous problem for voltages at the end of first iteration	92
Exa 18.4	Determine the set of load flow equations at the end of first iteration by using Newton Raphson method	93
Exa 18.5	Determine the equations at the end of first iteration after applying given constraints	95
Exa 19.1	To Determine the economic operating schedule and the corresponding cost of generation b Determine the savings obtained by loading the units	97
Exa 19.2	Determine the incremental cost of received power and penalty factor of the plant	98
Exa 19.4	Determine the minimum cost of generation	98
Exa 20.1	Determine the load taken by the set C and indicate the direction in which the energy is flowing	100
Exa 20.2	Determine the load shared by each machine	101
Exa 20.3	Determine the frequency to which the generated voltage drops before the steam flow commences to increase to meet the new load	101
Exa 21.1	Determine the load bus voltage	102
Exa 22.2	To Determine the source voltage when the load is disconnected to load pf i unity ii 8 lag	104
Exa 22.3	To determine the Ac system voltage when the dc system is disconnected or shutdown	105
Exa 22.4	To Calculate the new on and off times for constant energy	105
Exa 22.6	To discuss the effect of tap changing	106
Exa 22.7	To determine the effect of tapping to raise the secondary voltage by 10percent	106
Exa 22.8	Calculate the additional reactive power capability at full load	107
Exa 23.1	To determine the state vector at the end of first iteration	108
Exa 23.2	Determine The States of the systems at the end of first iteration	110
Exa 23.3	Problem on State Estimator Linear Model	111
Exa 23.4	Determine theta1 Theta2	111
Exa 24.3	Priority List Method	113

Exa 24.4	illustrate the dynamic programming for preparing an optimal unit commitment	114
Exa 25.1	illustrating the procedure for economic scheduling clear all	116

Chapter 1

FUNDAMENTALS OF POWER SYSTEMS

Scilab code Exa 1.1 To determine the Base values and pu values

To determine the Base values and pu values

```
1 // To determine the Base values and p.u values
2 clear
3 clc;
4 Sb=100; // base value of power(MVA)
5 Vb=33; // base value of voltage (Kv)
6 Vbl=Vb*110/32;
7 Vbm=Vbl*32/110;
8 Zp.ut=0.08*100*32*32/(110*33*33);
9 Zp.ul=50*100/(Vbl^2);
10 Zp.um1=.2*100*30*30/(30*33*33);
11 Zp.um2=.2*100*30*30/(20*33*33);
12 Zp.um3=.2*100*30*30/(50*33*33);
13 mprintf("Base value of voltage in line = %.2f kV\n", 
           Vbl);
14 mprintf("Base value of voltage in motor circuit=% .0f 
           kV\n", Vbm);
```

```
15 mprintf("p.u value of reactance transformer =%.5f p.  
u\n",Zp.ut);  
16 mprintf("p.u value of impedance of line=%.4f p.u\n",  
Zp.u.l);  
17 mprintf("p.u value of reactance of motor 1 =%.4f p.u  
\n",Zp.um1);  
18 mprintf("p.u value of reactance of motor 2 =%.3f p.u  
\n",Zp.um2);  
19 mprintf("p.u value of reactance of motor 3 =%.4f p.u  
\n",Zp.um3);
```

Chapter 2

LINE CONSTANT CALCULATIONS

Scilab code Exa 2.2 To determine inductance of a 3 phase line

To determine inductance of a 3 phase line

```
1 //To determine inductance of a 3 phase line
2 clear
3 clc;
4 GMD=0.7788*0.8/(2*100);
5 Mgmd=((1.6*3.2*1.6)^(1/3));
6 Z=2*(10^-4)*1000*log(2.015/.003115);
7 mprintf("The self GMD of the conductor =%.6f metres\n",GMD);
8 mprintf("The mutual GMD of the conductor =%.3f
metres\n",Mgmd);
9 mprintf("Inductance =%.3f mH/km\n",Z);
```

Scilab code Exa 2.3 Determine the equivalent radius of bundle conductor having its part conductors r on the periphery of circle of dia d

Determine the equivalent radius of bundle conductor having its part conductors r

```
1 //What will be the equivalent radius of bundle
  conductor having its part conductors 'r' on the
  periphery of circle of dia'd' if the number of
  conductors is 2,3,4 ,6 ?
2
3 clear
4 clc;
5 r=poly(0,"r");
6 D11=r^1;
7 D12=2*r;
8 D14=4*r
9 D13=sqrt(16-4)*r;
10 Ds1=((1*2*2*sqrt(3)*4*2*sqrt(3)*2*2)^(1/7))*r;
11 Ds7=((2*1*2*2**2*2*2)^(1/7))*r;//we get this after
  Taking r outside the 1/7th root
12 Ds=((((1*2*2*sqrt(3)*4*2*sqrt(3)*2*2)^(1/7))^6)
  *((2*1*2*2**2*2*2)^(1/7)))^(1/7)*r;
13 Dseq=(.7788)^(1/7)*Ds;
14 disp(Dseq,"Dseq.= ");
```

Scilab code Exa 2.4 To determine the inductance of single phase Transmission line

To determine the inductance of single phase Transmission line

```
1 // To determine the inductance of single phase
  Transmission line
2 clear
3 clc;
4 GMDa=0.001947; // GMD of conductor in group A
5 DSA=((.001947*6*12*.001947*6*6*0.001947*6*12)^(1/9))
  ;
```

```

6 DSB=sqrt(5*(10^-3)*.7788*6);
7 Dae=sqrt((9^2)+6^2);
8 Dcd=sqrt((12^2)+9^2);
9 DMA=((9*10.81*10.81*9*15*10.81)^(1/6));
10 LA=2*(10^-7)*(10^6)*log(DMA/DSA);
11 LB=2*(10^-7)*(10^6)*log(DMA/DSB);
12 Tot=LA+LB;
13 mprintf("inductance of line A,LA=%f mH/km\n",LA);
    //Answers don't match due to difference in
    rounding off of digits
14 mprintf("inductance of line B,LB=%f mH/km\n",LB);
    //Answers don't match due to difference in
    rounding off of digits
15 mprintf("total inductance of line =%f mH/km\n",Tot)
    ;//Answers don't match due to difference in
    rounding off of digits

```

Scilab code Exa 2.5 To determine the inductance per Km of 3 phase line

To determine the inductance per Km of 3 phase line

```

1 // To determine the inductance per Km of 3-phase
   line
2 clear
3 clc;
4 GMDc=1.266*0.7788*(10^-2); // self GMD of each
   conductor
5 Dbc=sqrt((4^2)+(7.5^2));
6 Dab=Dbc;
7 Dab '=sqrt((4^2)+(8.25^2));
8 Daa=sqrt((8^2)+(7.5^2));
9 Dm1=(Dbc*8*7.5*9.1685)^(1/4);
10 Dm2=(Dbc*Dbc*9.1685*9.1685)^(1/4);
11 Dm3=Dm1;
12 Dm=((Dm1*Dm2*Dm3)^(1/3));

```

```

13 Ds1=sqrt(GMDc*Daa); // self GMD of each phase
14 Ds3=Ds1;
15 Ds2=sqrt(GMDc*9);
16 Ds=((Ds1*Ds2*Ds3)^(1/3));
17 Z=2*(10^-4)*(1000)*log(Dm/Ds);
18 mprintf(" inductance=%f mH/km/phase\n",Z);

```

Scilab code Exa 2.6 To determine the inductance of double circuit line

To determine the inductance of double circuit line

```

1 // To determine the inductance of double circuit
   line
2 clear
3 clc;
4 GMDs=.0069; // self GMD of the conductor
5 Dab=sqrt((3^2)+.5^2);
6 Dbc=Dab;
7 Dac=6;
8 Dab '=sqrt((3^2)+6^2);
9 Daa=sqrt((6^2)+5.5^2);
10 Dm1=((3.04*6*5.5*6.708)^.25);
11 Dm2=((3.04*3.04*6.708*6.708)^.25);
12 Dm=4.89;
13 Ds1=sqrt(GMDs*Daa);
14 Ds2=0.2217;
15 Ds=.228;
16 Z=2*(10^-7)*(10^6)*log(Dm/Ds);
17 mprintf(" inductance =%f mH/km",Z);

```

Scilab code Exa 2.7 To determine the inductance per Km per phase of single circuit

To determine the inductance per Km per phase of single circuit

```
1 // // To determine the inductance per Km per phase  
  of single circuit  
2 clear  
3 clc;  
4 Ds=sqrt(0.025*.4*.7788);  
5 Dm=((6.5*13.0*6.5)^(1/3));  
6 Z=2*(10^-4)*1000*log(Dm/Ds);  
7 mprintf(" inductance =%.3f mH/km/phase" ,Z);
```

Chapter 3

CAPACITANCE OF TRANSMISSION LINES

Scilab code Exa 3.1 To determine the capacitance and charging current

To determine the capacitance and charging current

```
1 //To determine the capacitance and charging current
2 clear
3 clc;
4 Dm=2.015; // mutual GMD of conductors(m)
5 r=.4; // radius of conductor(cm)
6 C=10^-9*1000/(18*log(201.5/.4));
7 Ic=132*1000*8.928*314*(10^-9)/sqrt(3);
8 mprintf("capacitance =%.13 f F/km\n",C); //Answers don
      't match due to different reprentation
9 mprintf("charging current=% .4 f amp/km",Ic);
```

Scilab code Exa 3.2 To determine the capacitance and charging current

To determine the capacitance and charging current

```
1 //To determine the capacitance and charging current
2 clear
3 clc;
4 GMDm=6.61; //mutual GMD(m)
5 Ds1=sqrt(1.25*(10^-2)*10.965);
6 Ds3=Ds1;
7 Ds2=sqrt(1.25*(10^-2)*9);
8 Ds=((Ds1*Ds2*Ds3)^.333333);
9 C=1/(18*log(GMDm/Ds));
10 Ic=220*1000*314*.01905*(10^-6)/sqrt(3);
11 mprintf(" capacitance =%.6 f micro-Farad/km\n",C);
12 mprintf(" charging current =%.2 f amp/km" , Ic);
```

Scilab code Exa 3.3 To determine the capacitance and charging current

To determine the capacitance and charging current

```
1 //To determine the capacitance and charging current
2 clear
3 clc;
4 GMD=8.19;
5 Ds=sqrt(2.25*(10^-2)*.4);
6 C=1/(18*log(GMD/Ds));
7 Ic=220*1000*314*C*(10^-6)/sqrt(3);
8 mprintf(" capacitance per km =%.5 f micro-Farad\n",C);
9 mprintf(" charging current =%.3 f amp" , Ic);
```

Chapter 4

PERFORMANCE OF LINES

Scilab code Exa 4.1 To determine the sending end voltage and current power and power factor Evaluate A B C D parameters

To determine the sending end voltage and current power and power factor Evaluate A

```
1 //To detremine the the voltage at the generating  
    station and efficiency of transmission  
2 clear  
3 clc;  
4 R=0.496; // resistance  
5 X=1.536;  
6 Vr=2000;  
7 Z=(10*2*2/(11*11)) + %i*30*2*2/(11*11);  
8 Zt=(.04+(1.3*2*2/(11*11))) + %i*(.125 +  
    (4.5*2*2/(11*11))); //Transformer impedance  
9 I1=250*1000/2000; // line current (amps.)  
10 P1=I1*I1*R; //line loss (kW)  
11 Po=250*0.8; // output (kW)  
12 cosr=0.8; // power factor  
13 sinr=.6;  
14 %n=200*100/(200+7.7);  
15 Vs=(Vr*cosr+I1*R)+%i*(Vr*sinr+I1*X);  
16 V=sqrt((1662^2)+(1392^2));
```

```
17 mprintf(" efficiency= %.1f percent \n",%n);
18 mprintf(" Sending end voltage ,| Vs|=%.0f volts" ,V);
```

Scilab code Exa 4.2 To determine power input and output i star connected ii delta connected

To determine power input and output i star connected ii delta connected

```
1 //To determine power input and output (i) star
   connected (ii) delta connected
2 clear
3 clc;
4 mprintf("when load is star connected\n");
5 Vln=400/sqrt(3); // Line to neutral voltage(V)
6 Z=7+ %i*11; //Impedence per phase
7 I1=231/Z; // line current(amp.)
8 I=abs(231/Z);
9 Pi=3*I*I*7;
10 Po=3*I*I*6;
11 mprintf("power input =%.0f watts\n",Pi); //Answers
      don't match due to difference in rounding off of
      digits
12 mprintf("power output=% .0f watts\n",Po); //Answers
      don't match due to difference in rounding off of
      digits
13 mprintf("when load is delta connected\n");
14 Ze=2+ %i*3; // equivalent impedance(ohm)
15 Zp=3+ %i*5; // impedance per phase
16 il=231/Zp; //Line current(amps.)
17 IL=abs(il);
18 pi=3*IL*IL*3;
19 po=3*IL*IL*2;
20 mprintf("power input=% .1f watts\n",pi); //Answers don
      't match due to difference in rounding off of
      digits
```

```
21 mprintf("power output = %.0f watts \n",po); //Answers  
      don't match due to difference in rounding off of  
      digits
```

Scilab code Exa 4.3 To determine efficiency and regulation of line

To determine efficiency and regulation of line

```
1 // To determine efficiency and regulation of line  
2 clear  
3 clc;  
4 a=100/.5  
5 Xl=2*(10^-7)*log(100/.5); // inductance (H/meter)  
6 XL=20*(1000)*Xl; // inductance of 20 km length  
7 R=6.65; // resistance (ohm)  
8 Rc=20*1000/(58*90); // resistance of copper (ohm)  
9 I=10*1000/(33*.8*sqrt(3)); // the current (amps.)  
10 P1=3*I*I*Rc/(10^6); // loss (MW)  
11 n=10/(10+P1);  
12 mprintf("efficiency=% .4f percent \n",n);  
13 Vr=19052;  
14 cosr=.8; // power factor  
15 sinr=.6;  
16 Vs=abs(((Vr*cosr+I*Rc) +%i*(Vr*sinr+ I*R)));  
17 mprintf("Vs =%.0f volts\n",Vs); // Answer don't match  
      due to difference in rounding off of digits  
18 Reg=(Vs-Vr)*100/Vr;  
19 mprintf(" regulation =%.2f percent",Reg)
```

Scilab code Exa 4.4 To calculate the voltage across each load impedance and current in the neutral

To calculate the voltage across each load impedance and current in the neutral

```

1 //To calculate the voltage across each load
    impedance and current in the neutral
2 clear
3 clc;
4 IR=(400)/((sqrt(3)*(6.3+%i*9)));
5 IY=231*(cosd(-120) + %i*sind(-120))/8.3;
6 IB=231*(cosd(120) + %i*sind(120))/(6.3-%i*8);
7 In=abs((IR +IY +IB)); //Neutral current
8 mprintf("Neutral current =%.2f amps\n",In);
9 VR=abs(IR*(6+ %i*9));
10 VY=abs(IY*(8));
11 VB=abs(IB*(6-%i*8));
12 mprintf("Voltage across Phase R =%.1f volts \n",VR);
13 mprintf("Voltage across Phase Y =%.2f volts \n",VY);
14 mprintf("Voltage across Phase B =%.0f volts \n",VB);

```

Scilab code Exa 4.5 To determine efficiency and regulation of 3 phase line

To determine efficiency and regulation of 3 phase line

```

1 // To determine efficiency and regulation of 3 phase
    line
2 clear
3 clc;
4 R=100*.1; //Resistance of line (ohm)
5 Xl=2*(10^-7)*100*1000*log(200/.75); //inductance of
    line
6 X2=Xl*314; //inductive reactance
7 C=2*(%pi*100)*8.854*(10^-12)*100*1000*(10^6)/(log
    (200/.75)); // capacitance per phase (micro farad)
8 mprintf("Using Nominal-T method\n");
9 Ir=20*1000/(sqrt(3)*66*.8);
10 Vr=66*1000/sqrt(3);
11 Vc=(38104*.8+ Ir*5) +%i*(38104*.6+ Ir*17.55); //
    voltage across condenser

```

```

12 Ic=%i*314*(Vc)*.9954*(10^-6);
13 is=Ir+Ic;
14 Is=abs(Ir+Ic);
15 Vs=abs(Vc + (is*(5 + %i*17.53)));
16 VR=abs(Vs*(-%i*3199)/(5-%i*3181)); // no load
    recieving end voltage
17 Reg=(VR-Vr)*100/Vr;
18 P1=3*(Ir*Ir*5 + Is*Is*5)/1000000;
19 %n=20*100/(20+P1);
20 mprintf(" percent regulation=%f \n",Reg);
21 mprintf(" percent efficiency=%f \n\n",%n);
22 mprintf(" Using Nominal-pi method\n");
23 Ir1=218.68*(.8-%i*.6);
24 Ic1=%i*314*.4977*(10^-6)*Vr;
25 Il=Ir1+Ic1;
26 vs1=Vr+Il*(10+%i*35.1);
27 Vs1=abs(vs1);
28 Vr1=Vs1*(-%i*6398)/(10-%i*6363);
29 VR1=abs(Vr1); // no load recieving end voltage
30 Reg2=(VR1-Vr)*100/Vr;
31 IL=abs(Ir1+Ic1);
32 Loss=3*IL*IL*10;
33 %n=20*100/21.388;
34 mprintf(" percent regulation=%f \n",Reg2);
35 mprintf(" percent efficiency=%f \n",%n);

```

Scilab code Exa 4.6 To find the rms value and phase values i The incident voltage to neutral at the receiving end ii The reflected voltage to neutral at the receiving end iii The incident and reflected voltage to neutral at 120 km from the receiving end

To find the rms value and phase values i The incident voltage to neutral at the re

```

1 //To find the rms value and phase values (i)The
    incident voltage to neutral at the receiving end

```

(ii)The reflected voltage to neutral at the
 recieving end (iii)The incident and reflected
 voltage to neutral at 120 km from the recieving
 end .

```

2 clear
3 clc;
4 R=0.2;
5 L=1.3;
6 C=0.01*(10^-6);
7 z=R+%i*L*314*(10^-3); // serie impedance
8 y=%i*314*C; // shunt admittance
9 Zc=sqrt(z/y); // characterstic impedance
10 Y=sqrt(y*z);
11 Vr=132*1000/sqrt(3);
12 Ir=0;
13 Vin=(Vr + Ir*Zc)/2; // incident voltage to neutral at
    the recieving end
14 mprintf("Vr =%.3f volts \n",Vr); //Answer don't match
    due to difference in rounding off of digits
15 mprintf("(i)The incident voltage to neutral at the
    recieving end =%.3f volts \n",Vin); //Answer don't
    match due to difference in rounding off of
    digits
16 Vin2=(Vr - Ir*Zc)/2; // The reflected voltage to
    neutral at the recieving end
17 mprintf("(ii)The reflected voltage to neutral at the
    recieving end=%.3f volts \n",Vin2); //Answer don'
    t match due to difference inrounding off of
    digits
18 Vrp=Vr*exp(.2714*120*(10^-3))*exp(%i
    *1.169*120*(10^-3))/1000; //Taking Vrp=Vr+
19 Vrm=Vr*exp(-0.0325)*exp(-%i*.140)/1000; //Taking Vrm=
    Vr-
20 v1=Vrm/2; // reflected voltage to neutral at 120 km
    from the recieving end
21 phase_v1=atand(imag(v1)/real(v1)); //Phase angle of
    v1
22 v2=Vrp/2; //incident voltage to neutral at 120 km

```

```

        from the receiving end
23 phase_v2=atan(imag(v2)/real(v2)); //Phase angle of
    v2
24 mprintf("(iii) reflected voltage to neutral at 120
    km from the receiving end =%.2f at angle of %.2f
    \n",abs(v1),phase_v1);
25 mprintf("incident voltage to neutral at 120 km from
    the receiving end =%.2f at angle of %.2f\n",abs(
    v2),phase_v2);

```

Scilab code Exa 4.7 To determine of efficiency of line

To determine of efficiency of line

```

1 //To determine of efficiency of line
2 clear
3 clc;
4 Ir=40*1000/(sqrt(3)*132*.8);
5 Vr=132*1000/sqrt(3);
6 Zc=380*(cosd(-13.06)+ %i*sind(-13.06));
7 IR=Ir*(cosd(-36.8)+ %i*sind(-36.8));
8 Vsp=(Vr+IR*Zc)*(1.033*(cosd(8.02)+ %i*sind(8.02)))
    /2;
9 Vsm=(Vr-IR*Zc)*( .968*(cosd(-8.02)+ %i*sind(-8.02)))
    /2;
10 vs=Vsp+ Vsm;
11 Vs=abs(vs);
12 is=(Vsp-Vsm)/Zc;
13 Is=abs(is)
14 P=3*Vs*Is*cosd(33.72)/10^6;
15 n=40*100/P;
16 mprintf(" efficiency=%.1f",n); //Answer don't match
    due to difference in rounding off of digits

```

Scilab code Exa 4.8 To determine the ABCD parameters of Line

To determine the ABCD parameters of Line

```
1 //To determine the ABCD parameters of Line
2 clear
3 clc;
4 yl=(0.2714+ %i*1.169)*120*(10^-3);
5 IR=40*1000/(sqrt(3)*132*.8)
6 A=cosh(yl);
7 phase_A=atand(imag(A)/real(A)); //Phase angle of A
8 IR=IR*(cosd(-36.8)+ %i*sind(-36.8))
9 Vr=132*1000/sqrt(3);
10 Zc=380*(cosd(-13.06)+ %i*sind(-13.06));
11 B=Zc*sinh(yl);
12 phase_B=atand(imag(B)/real(B)); //Phase angle of B
13 Vs=(A*Vr+B*IR);
14 f=abs(B);
15 d=abs(Vs);
16 C=sinh(yl)/Zc;
17 phase_C=atand(imag(C)/real(C)); //Phase angle of C
18 D=cosh(yl);
19 phase_D=atand(imag(D)/real(D)); //Phase angle of D
20 mprintf("A=%f at an angle of %f \n",abs(A),
phase_A)
21 mprintf("B=%f at an angle of %f \n",abs(B),
phase_B)
22 mprintf("C=%f at an angle of %f \n",abs(C),
phase_C)
23 mprintf("D=%f at an angle of %f \n",abs(D),
phase_D)
```

Scilab code Exa 4.9 To determine the sending end voltage and efficiency using Nominal pi and Nominal T method

To determine the sending end voltage and efficiency using Nominal pi and Nominal T

```

1 //To determine the sending end voltage and
   efficiency using Nominal_pi and Nominal-T method
2 clear
3 clc;
4 Ir=218.7*(.8-%i*.6);
5 Ic1=%i*314*.6*(10^-6)*76200;
6 Il=Ic1+Ir;
7 Vs=76200 + Il*(24+ %i*48.38);
8 phase_Vs=atand(imag(Vs)/real(Vs)); //phase angle of
   VS
9 P1=3*24*abs(Il)*abs(Il)/1000000; //The Loss (MW)
10 n=40*100/(40+P1);
11 mprintf(" Using Nominal- pi method\n ");
12 mprintf("Vs=%.0 f volts at an angle of %.2 f \n",abs(
   Vs),phase_Vs)
13 mprintf(" efficiency=% .2 f percent\n ",n);
14 mprintf("\nUsing Nominal-T method\n");
15 Vc=76200*(.8+%i*.6) + 218.7*(12+ %i*24.49);
16 Ic=%i*314*1.2*(10^-6)*(63584+ %i*51076);
17 Is=199.46+ %i*23.95;
18 Vs=(Vc + Is*(12+ %i*24.49))/1000;
19 phase_Vs=atand(imag(Vs)/real(Vs)); //Phase angle of
   VS
20 P11=3*12*((200.89^2)+ 218.7^2)/1000000; //The loss (MW
   )
21 n1=40*100/(40+P11);
22 mprintf("Vs=% .2 f at an angle of %.2 f \n",abs(Vs),
   phase_Vs)
23 mprintf(" efficiency=% .2 f percent\n ",n1);

```

Scilab code Exa 4.10 To determine the sending end voltage and current power and power factor Evaluate A B C D parameters

To determine the sending end voltage and current power and power factor Evaluate A

```
1 // To determine the sending end voltage and current
   , power and power factor. Evaluate A, B , C, D
   parameters .
2 clear
3 clc;
4 R=.1557*160
5 GMD=(3.7*6.475*7.4)^(1/3);
6 Z1=2*(10^-7)*log(560/.978)*160*1000;
7 XL=63.8;
8 C=(10^-9)*2*(10^6)*%pi*160*1000/(36*%pi*log
   (560/.978));
9 Z=sqrt((.1557^2) + .39875^2)*(cosd(68.67)+ %i*sind
   (68.67));
10 jwC=%i*314*1.399*(10^-6)/160;
11 Zc=sqrt(Z/jwC);
12 y=sqrt(Z*jwC);
13 yl=y*160;
14 A=cosh(yl);
15 B=Zc*sinh(yl)
16 C=sinh(yl)/Zc;
17 Ir=50000/(sqrt(3)*132);
18 Vs=(A*76.208) +(B*(10^-3)*Ir*(cosd(-36.87)+%i*sind
   (-36.87)));
19 VS=152.34;
20 Is=C*76.208*(10^3) +(A*Ir*(cosd(-36.87)+%i*sind
   (-36.87)));
21 Ps=3*abs(Vs)*abs(Is)*cosd(33.96);
22 pf=cosd(33.96);
23 Vnl=abs(Vs)/abs(A);
24 reg=(Vnl-76.208)*100/76.208;
25 n=50000*.8*100/abs(Ps);
26 mprintf(" Vs line to line =%.2f kV\n",VS);
```

```
27 disp(Is,"sending end current Is(A)=%"); //Answer don't  
     match due to difference in rounding off of  
     digits  
28 mprintf("sending end power=%0.0f kW\n",Ps);  
29 mprintf("sending end p.f =%0.3f\n",pf);  
30 mprintf("percent regulation=%0.1f \n",reg);  
31 mprintf("percent efficiency=%0.1f ",n);
```

Chapter 5

HIGH VOLTAGE DC TRANSMISSION

Scilab code Exa 5.1 To determine the dc output voltage when delay anglw
a0 b30 c45

To determine the dc output voltage when delay anglw a0 b30 c45

```
1 //To determine the d.c. output voltage when delay
   anglw (a)0 (b)30 (c)45
2 clear
3 clc;
4 Vo=3*sqrt(2)*110/%pi;
5 Vd=Vo*(cosd(0) + cosd(15))/2;
6 Vd1=Vo*(cosd(30) + cosd(45))/2;
7 Vd2=Vo*(cosd(45) + cosd(60))/2;
8 mprintf("(a) For a=0, Vd=%f kV\n",Vd);
9 mprintf("(b) For a=30,Vd=%f kV\n",Vd1);
10 mprintf("(c) For a=45,Vd=%f kV\n",Vd2);
```

Scilab code Exa 5.2 To determine the necessary line secondary voltage
and tap ratio required

To determine the necessary line secondary voltage and tap ratio required

```
1 // To determine the necessary line secondary voltage  
    and tap ratio required .  
2 clear  
3 clc ;  
4 VL=100*2*%pi/(3*sqrt(2)*(cosd(30) + cosd(45)));  
5 mprintf ("VL=%f kV\n",VL); // Answers don't match due  
    to difference in rounding off of digits  
6 Tr=VL/110;  
7 mprintf ("tap ratio=%f \n",Tr);

---


```

Scilab code Exa 5.3 To determine the effective reactance per phase

To determine the effective reactance per phase

```
1 // To determine the effective reactance per phase  
2 clear  
3 clc ;  
4 Vd=100000;  
5 Id=800; // current  
6 X=((3*sqrt(2)*94.115*.866*1000/%pi)-Vd)*%pi/(3*Id);  
7 mprintf (" effective reactance per phase , X=%f ohm\n",X); // Answer don't match due to difference in  
    rounding off of digits

---


```

Scilab code Exa 5.4 Calculate the direct current delivered

Calculate the direct current delivered

```
1 //Calculate the direct current delivered
2 clear
3 clc;
4 a=15;
5 d0=10;
6 y=15;
7 X=15;
8 R=10;
9 Id=(3*sqrt(2)*120*(cosd(a)-cosd(d0+y))*1000)/((R +
    (3*2*X)/%pi)*%pi);
10 mprintf(" Id=% .2 f amp.\n" ,Id);
```

Chapter 6

CORONA

Scilab code Exa 6.1 To determine the critical disruptive voltage and critical voltage for local and general corona

To determine the critical disruptive voltage and critical voltage for local and ge

```
1 //To determine the critical disruptive voltage and  
  critical voltage for local and general corona.  
2 clear  
3 clc;  
4 t=21; // air temperature  
5 b=73.6; // air pressure  
6 do=3.92*73.6/(273+t);  
7 m=.85;  
8 r=.52;  
9 d=250;  
10 Vd=21.1*m *do*r*log(250/.52);  
11 vd=sqrt(3)*Vd;  
12 m=.7;  
13 vv=21.1*m*do*r*(1+ (.3/sqrt(r*do)))*log(250/.52);  
14 Vv=vv*sqrt(3);  
15 Vvg=Vv*.8/.7;  
16 mprintf(" critical disruptive line to line voltage=%  
 .2 f kV \n",vd);
```

```
17 mprintf(" visual critical voltage for local corona=%
.2 f kV \n",vv);
18 mprintf(" visual critical voltage for general corona=
%.2 f kV \n",Vvg);
```

Scilab code Exa 6.2 To determine whether corona will be present in the air space round the conductor

To determine whether corona will be present in the air space round the conductor

```
1 // To determine whether corona will be present in
   the air space round the conductor
2 clear
3 clc;
4 d=2.5;
5 di=3; // internal diameter
6 do=9; // external diameter
7 ri=di/2;// internal radius
8 ro=do/2;// external diameter
9 g1max=20/(1.25*log(ri/(d/2))+ .208*1.5*log(ro/ri));
10 mprintf("g1max=%0.0 f kV/cm \n",g1max);
11 mprintf(" Since the gradient exceeds 21.1/kV/cm ,
corona will be present.")
```

Scilab code Exa 6.3 To determine the critical disruptive voltage and corona loss

To determine the critical disruptive voltage and corona loss

```
1 // To determine the critical disruptive voltage and
   corona loss
2 clear
```

```
3 clc;
4 m=1.07;
5 r=.625
6 V=21*m *r*log(305/.625);
7 Vl=V*sqrt(3);
8 fprintf(" critical disruptive voltage=%f kV\n",V);
9 fprintf(" since operating voltage is 110 kV , corona
loss= 0 ");
```

Scilab code Exa 6.4 To determine the voltage for which corona will commence on the line

To determine the voltage for which corona will commence on the line

```
1 //To determine the voltage for which corona will
   commence on the line
2 clear
3 clc;
4 r=.5;
5 V=21*r*log(100/.5);
6 fprintf(" critical disruptive voltage=%f kV",V);
```

Scilab code Exa 6.5 To determine the corona characterstics

To determine the corona characterstics

```
1 //To determine the corona characterstics
2 clear
3 clc;
4 D=1.036; // conductor diameter(cm)
5 d=2.44; //delta spacing(m)
6 r=D/2; //radius(cm)
```

```

7 Ratio=d*100/r;
8 j=r/(d*100);
9 Rat2=sqrt(j);
10 t=26.67; //temperature
11 b=73.15; // barometric pressure
12 mv=.72;
13 V=63.5;
14 f=50; //frequency
15 do=3.92*b/(273+t); //do=dell
16 vd=21.1*.85*do*r*log(Ratio);
17 mprintf(" critical disruptive voltage=%f kV\n",vd);
18 Vv=21.1*mv*do*r*(1+ (.3/sqrt(r*do)))*log(Ratio);
19 P1=241*(10^-5)*(f+25)*Rat2*((V-vd)^2)/do; //power
    loss
20 Vd=.8*vd;
21 P12=241*(10^-5)*(f+25)*Rat2*((V-Vd)^2)*160/do; //loss
    per phase /km
22 Total= 3*P12;
23 mprintf(" visual critical voltage=%f kV\n",Vv);
24 mprintf("Power loss=%f kW/phase/km\n",P1);
25 mprintf("under foul weather condition ,\n");
26 mprintf(" critical disruptive voltage=%f kV\n",Vd);
27 mprintf(" Total loss=%f kW\n",Total);

```

Chapter 7

MECHANICAL DESIGN OF TRANSMISSION LINES

Scilab code Exa 7.1 Calculate the sag

Calculate the sag

```
1 // Calculate the sag
2 clear
3 clc;
4 sf=5; // Factor of safety
5 d=.95; // conductor dia(cm)
6 Ws=4250/sf; // working stress(kg/cm_2)
7 A=%pi*(d^2)/4; // area (cm_2)
8 Wp=40*d*(10^-2); // wind pressure (kg/cm)
9 W=sqrt((.65^2) +(.38^2)); // Total effective weight(
    kg/m)
10 T=850*A; // working tension (kg)
11 c=T/W;
12 l=160;
13 d=l^2/(8*800);
14 mprintf ("sag ,d=%.0 f metres\n",d);
```

Scilab code Exa 7.2 To calculate the maximum Sag

To calculate the maximum Sag

```
1 // To calculate the maximum Sag
2 clear
3 clc;
4 D=1.95 + 2.6; // overall diameter (cm)
5 A=4.55*(10^-2); // area (m_2)
6 d=19.5; // diameter of conductor (mm)
7 r=d/2; // radius of conductor (mm)
8 Wp=A*39; // wind pressure (kg/m_2)
9 t=13; // ice coating (mm)
10 US=8000; // ultimate strength (kg)
11 Aice=%pi*(10^-6)*((r+t)^2 - r^2); // area section of
    ice (m_2)
12 Wice=Aice*910;
13 W=(sqrt(.85+Wice)^2 + Wp^2)); // total weight of ice
    (kg/m)
14 T=US/2; // working tension (kg)
15 c=T/W;
16 l=275; // length of span (m)
17 Smax=l*l/(8*c);
18 mprintf("Maximum sag=%f metres\n",Smax);
```

Scilab code Exa 7.3 To determine the Sag

To determine the Sag

```
1 //To determine the Sag
2 clear
```

```

3 clc;
4 A=13.2; // cross section of conductor (mm_2)
5 Ar=4.1*(10^-3); // projected area
6 Wp=Ar*48.82; // wind loadind /m(kg/m)
7 w=.115;
8 W=sqrt((.1157^2) + (Wp^2)); // effective loading per
metre(kg)
9 q1=W/.115;
10 b=w/A;
11 f1=21; //working stress
12 T1=f1*A;
13 c=T1/W;
14 l=45.7;
15 S=l*l/(8*c);
16 dT=32.2-4.5; // difference in temperature
17 E=1.26*(10000);
18 a=16.6*(10^-6);
19 d=8.765*(10^-3);
20 K=f1-((l*d*q1)^2)*E/(24*f1*f1);
21 p=poly([-84.23 0 -14.44 1], 'f2', 'c');
22 r=roots(p);
23 f2= 14.823332; // accepted value of f2
24 T=f2*A;
25 c=T/w;
26 d1=l*l/(8*c);
27 mprintf("sag at 32.2 Celsius , d=% .4f metres",d1);

```

Scilab code Exa 7.4 To determine the clearance between the conductor and water level

To determine the clearence between the conductor and water level

```

1 // To determine the clearence between the conductor
and water level
2 clear

```

```
3 clc;
4 T=2000; // working tension (kg)
5 w=1;
6 c=T/w;
7 h=90-30;
8 l=300; //span(m)
9 a=(l/2)-(c*h/l);
10 b=550;
11 d1=a*a/(2*c);
12 d2=(400^2)/(2*c); // sag at 400 metres(m)
13 Hm=d2-d1; //height of mid point with respect to A
14 C1=30+Hm;
15 mprintf("the clearence between the conductor and
water level midway between the towers= %.3 f
metres \n",C1);
```

Chapter 8

OVERHEAD LINE INSULATORS

Scilab code Exa 8.1 To determine the maximum voltage that the string of the suspension insulators can withstand

To determine the maximum voltage that the string of the suspension insulators can

```
1 // To determine the maximum voltage that the string
   of the suspension insulators can withstand .
2 clear
3 clc;
4 E3=17.5;
5 E1=64*E3/89;
6 E2=9*E1/8;
7 E=E1+E2+E3;
8 mprintf ("the maximum voltage that the string of the
   suspension insulators can withstand=%.2f kV\n",E)
;
```

Chapter 9

INSULATED CABLES

Scilab code Exa 9.1 To determine the economic overall diameter of a 1core cable metal sheathhead

To determine the economic overall diameter of a 1core cable metal sheathhead

```
1 // To determine the economic overall diameter of a
   1- core cable metal sheathhead .
2 clear
3 clc;
4 V=85; // working voltage (kV)
5 gmax=65; // dielectric strength of insulating
   material (kV/cm)
6 r=V/gmax;
7 d=2*r;
8 D=2.6*e;
9 mprintf ("Diameter of the sheath =%.2f cm\n",D);
```

Scilab code Exa 9.2 To determine the minimum internal diameter of the lead sheath

To determine the minimum internal diameter of the lead sheath

```

1 // To determine the minimum internal diameter of the
   lead sheath
2 clear
3 clc;
4 e1=4;
5 e2=4;
6 e3=2.5;
7 g1max=50;
8 g2max=40;
9 g3max=30;
10 r=.5; // radius (cm)
11 r1=r*e1*g1max/(e2*g2max);
12 r2=r1*e2*g2max/(e3*g3max);
13 V=66;
14 lnc=(V-((r*g1max*log(r1/r))+(r1*g2max*log(r2/r1)))) ;
15 m=lnc/(r2*g3max);
16 R=r2*(%e^m);
17 D=2*R;
18 fprintf("minimum internal diameter of the lead
sheath ,D=%.2f cms\n",D);

```

Scilab code Exa 9.3 To determine the maximum safe working voltage

To determine the maximum safe working voltage

```

1 // To determine the maximum safe working voltage
2 clear
3 clc;
4 r=.5; // radius of conductor (cm)
5 g1max=34;
6 er=5;
7 r1=1;
8 R=7/2; // external dia (cm)
9 g2max=(r*g1max)/(er*r1);
10 V=((r*g1max*log(r1/r))+(r1*g2max*log(R/r1)));

```

```
11 V=V/(sqrt(2));
12 mprintf("Maximum safe working voltage ,V =%.2f kV r
.m.s\n",V);
```

Scilab code Exa 9.4 To determine the maximum stresses in each of the three layers

To determine the maximum stresses in each of the three layers

```
1 //To determine the maximum stresses in each of the
   three layers .
2 clear
3 clc;
4 r=.9;
5 r1=1.25
6 r2=r1+.35;
7 r3=r2+.35; // radius of outermost layer
8 Vd=20; // voltage difference (kV)
9 g1max=Vd/(r*log(r1/r));
10 g2max=Vd/(r1*log(r2/r1));
11 g3max=(66-40)/(r2*log(r3/r2));
12 mprintf("g1max =%.1f kV/cm\n",g1max);
13 mprintf("g2max =%.2f kV/cm\n",g2max);
14 mprintf("g3max =%.0f kV/cm\n",g3max);
```

Scilab code Exa 9.5 o dtermine the equivalent star connected capacity and the kVA required

o dtermine the equivalent star connected capacity and the kVA required

```
1 //To dtermine the equivalent star connected capacity
   and the kVA required .
```

```

2 clear
3 clc;
4 V=20; // voltage (kV)
5 w=314;
6 C=2*3.04*10^-6; //capacitance per phase(micro-farad)
7 KVA=V*V*w*C*1000;
8 mprintf("3-phase kVA required =%.0f kVA",KVA); //
    Answer don't match due to difference in rounding
    off of digits

```

Scilab code Exa 9.6 Determine the capacitance a between any two conductors b between any two bunched conductors and the third conductor c
Also calculate the charging current per phase per km

Determine the capacitance a between any two conductors b between any two bunched c

```

1 // Determine the capacitance (a)between any two
    conductors (b)between any two bunched conductors
    and the third conductor (c)Also calculate the
    charging current per phase per km
2 clear
3 clc;
4 C1=.208;
5 C2=.096;
6 Cx=3*C1;
7 w=314;
8 V=10;
9 Cy=(C1+ 2*C2);
10 Co=((1.5*Cy)-(Cx/6));
11 C=Co/2;
12 mprintf("( i )Capacitance between any two conductors=%
    .3 f micro-Farad/km\n",c);
13 c=((2*C2 + ((2/3)*C1)));
14 mprintf("( ii )Capacitance between any two bunched
    conductors and the third conductor=% .2 f micro-
    Farad/km\n",c);

```

```
15 I=V*w*Co*1000*(10^-6)/sqrt(3);  
16 mprintf("(iii) the charging current per phase per km  
=%.3f A\n",I);
```

Scilab code Exa 9.7 To calculate the induced emf in each sheath

To calculate the induced emf in each sheath

```
1 // To calculate the induced emf in each sheath .  
2 clear  
3 clc;  
4 rm=(2.28/2)-(1.52/2); // mean radius of sheath (cm)  
5 d=5.08;  
6 a=d/rm;  
7 w=314;  
8 Xm=2*(10^-7)*log(a); // mutual inductance (H/m)  
9 Xm2=2000*Xm;  
10 V=w*Xm2*400;  
11 mprintf("Voltage induced =%.2f volts \n",V); //Answer  
don't match exactly due to difference in  
rounding off of digits in between calculations
```

Scilab code Exa 9.8 To determine the ratio of sheath loss to core loss of the cable

To determine the ratio of sheath loss to core loss of the cable

```
1 //To determine the ratio of sheath loss to core loss  
of the cable  
2 clear  
3 clc;  
4 R=2*.1625;
```

```
5 Rs=2*2.14;
6 M=314;
7 w=6.268*10^-4;
8 r=Rs*M*M*w*w/(R*((Rs^2)+(M*M*w*w)));
9 mprintf(" ratio=% .4 f \n" ,r);
```

Chapter 10

VOLTAGE CONTROL

Scilab code Exa 10.1 To determine the total power active and reactive supplied by the generator and the pf at which the generator must operate

To determine the total power active and reactive supplied by the generator and the pf at which the generator must operate

```
1 // To determine the total power , active and  
  reactive , supplied by the generator and the p.f  
  at which the generator must operate .  
2 clear  
3 clc;  
4 V=1; // voltage (p.u)  
5 Pa=.5; // active power at A (p.u)  
6 Pr=.375; // reactive power at A(p.u)  
7 Xca=0.075+0.04; // reactance between C and A  
8 P1=((Pa^2)+(Pr^2))*Xca/(V^2);  
9 pac=1.5;  
10 prc=2;  
11 Pta=.5+1.5; // total active power between E and C  
12 Ptr=Pr+P1+2; // reactive power between E and C  
13 Xt=.05+.025; //total reactance beteween E an C  
14 P12=((2*2) + (2.4199^2)); // loss (p.u)  
15 Pat=200;  
16 Prt=315.9;
```

```

17 pf=.5349;
18 mprintf("Total active power supplied by generator =%
.0 f MW\n",Pat);
19 mprintf("Total reactive power supplied by generator
=%f MW \n",Prt);
20 mprintf("p. f of the generator =%.4 f \n",pf);

```

Scilab code Exa 10.2 Determine the settings of the tap changers required to maintain the voltage of load bus bar

Determine the settings of the tap changers required to maintain the voltage of load bus bar

```

1 // Determine the settings of the tap changers
   required to maintain the voltage of load bus bar
2 clear
3 clc;
4 l1=150;
5 tstr=1;
6 load2=72.65;
7 R=30;
8 P=(l1*(10^6))/3;
9 X=80;
10 Q=(load2*(10^6))/3;
11 Vs=(230*(10^3))/sqrt(3);
12 Vr=Vs;
13 ts2=1/((R*P)+(X*Q))/(Vs*Vr));
14 ts=sqrt(ts2);
15 mprintf("ts=%f p.u\n",ts);

```

Scilab code Exa 10.3 i Find the sending end Voltage and the regulation of line ii Determine the reactance power supplied by the line and by synchronous capacitor and pf of line iii Determine the maximum power transmitted

i Find the sending end Voltage and the regulation of line ii Determine the reactance

```
1 // (i) Find the sending end Voltage and the
      regulation of line (ii) Determine the reactance
      power supplied by the line and by synchronous
      capacitor and p.f of line (iii)Determine the
      maximum power transmitted
2 clear
3 clc;
4 A=.895;
5 Vr=215;
6 B=182.5;
7 x=A*(Vr^2)/B;
8 y=78.6-1.4; //b-a
9 p=acosd(.9);
10 X1=x/50;
11 Vs=265*182.5/215;
12 Vr1=Vs/A;
13 Reg=100*(Vr1-Vr)/Vr;
14 mprintf("( i ) sending end voltage (kV)=%.1f kV\n",Vs)
        ;
15 mprintf(" receiving end voltage =%.0f kV\n",Vr1);
16 mprintf(" Regulation = %.2f percent\n",Reg);
17 Vs1=236;
18 Q=Vs1*Vr/B;
19 QP=.25*50;
20 PR=.50*50;
21 cosQ=.958;
22 mprintf("\n( ii )QP(MVAr)=%.1f MV Ar\n",QP);
23 mprintf(" PR(MVAr)=%.0f MV Ar\n",PR);
24 mprintf("CosQ=% .3f \n",cosQ);
25 MN=4.55;
26 Sbmax=MN*50;
27 mprintf("maximum power transmitted =%.1f MW\n",Sbmax
        );
```

Scilab code Exa 10.4 Determine the KV Ar of the Modifier and the maximum load that can be transmitted

Determine the KV Ar of the Modifier and the maximum load that can be transmitted

```
1 // Determine the KV Ar of the Modifier and the
   maximum load that can be transmitted
2 clear
3 clc;
4 a=0;
5 b=73.3
6 A=1;
7 B=20.88;
8 Vs=66;
9 Vr=66;
10 Load=75;
11 p=poly([14624 400 1] , 'Qr' , 'c');
12 r=roots(p);
13 Qr=- 40.701538;
14 C=-Qr + (75*.6/.8);
15 Smax=(Vr^2)*(1-cosd(b))/B;
16 mprintf("The phase modifier capacity =%.2f MV Ar\n",
          C);
17 mprintf("Maximum power transmitted ,Pmax =%.2f MW",
          Smax);
```

Chapter 11

NEUTRAL GROUNDING

Scilab code Exa 11.1 To find the inductance and KVA rating of the arc suppressor coil in the system

To find the inductance and KVA rating of the arc suppressor coil in the system

```
1 // To find the inductance and KVA rating of the arc
   suppressor coil in the system
2 clear
3 clc;
4 C1=2*%pi*(10^-9)/(36*%pi*log((4*4*8)^(1/3)
   /(10*(10^-3)))); 
5 C=C1*192*(10^9); // capacitance per phase (micro
   farad)
6 L=(10)^6/(3*314*314*C);
7 V=132; //voltage (kV)
8 MVA=V*V/(3*314*L);
9 mprintf("inductance ,L=%f H\n",L);
10 mprintf("MVA rating of suppressor coil =%f MVA
   per coil",MVA);
```

Scilab code Exa 11.2 Determine the reactance to neutralize the capacitance of i 100 percent of the length of line ii 90 percent of the length of line
iii 80 percent of the length of line

Determine the reactance to neutralize the capacitance of i 100 percent of the leng

```
1 // Determine the reactance to neutralize the
   capacitance of (i)100% of the length of line (ii)
   90% of the length of line (iii)80% of the length
   of line
2 clear
3 clc;
4 wL=1/(3*314*(10)^-6);
5 mprintf("(i) inductive reactance for 100 percent of
   the length of line=%.1f ohms\n",wL);
6 wL=10^6/(3*314*.9);
7 mprintf("(ii) inductive reactance for 90 percent of
   the length of line=%.1f ohms\n",wL);
8 wL=1/(3*314*(10)^-6)/.8;
9 mprintf("(iii) inductive reactance for 80 percent of
   the length of line=%.1f ohms\n",wL);
```

Chapter 12

TRANSIENTS IN POWER SYSTEMS

Scilab code Exa 12.1 To determine the i the neutral impedance of line ii line current iii rate of energy absorption rate of reflection and state form of reflection iv terminating resistance v amount of reflected and transmitted power

To determine the i the neutral impedance of line ii line current iii rate of energ

```
1 // To determine the (i)the neutral impedance of line  
    (ii)line current (iii)rate of energy absorption  
    , rate of reflection and state form of reflection  
    (iv) terminating resistance (v)amount of  
    reflected and transmitted power  
2 clear  
3 clc;  
4 L=2*(10^-7)*log(100/.75); //inductance per unit  
    length  
5 C=2*pi*(10^-9)/(36*pi*log(100/.75)); //Capacitance  
    per phase per unit length (F/m)  
6 Z1=sqrt(L/C);  
7 E=11000;
```

```

8 mprintf("(i) the natural impedance of line=%.0f ohms\
n",Z1);
9 I1=E/(sqrt(3)*Z1); //line current (amps)
10 mprintf("(ii) line current =%.1f amps\n",I1);
11 R=1000;
12 Z2=R;
13 E1=2*Z2*E/((Z1+Z2)*sqrt(3));
14 Pr=3*E1*E1/(R*1000); //Rate of power consumption
15 Vr=(Z2-Z1)*E/(sqrt(3)*(Z2+Z1)*1000); //Reflected
    voltage
16 Er=3*Vr*Vr*1000/Z1 //rate of reflected voltage
17 mprintf("(iii) rate of energy absorption =%.1f kW\n",Pr);
18 mprintf("rate of reflected energy =%.1f kW\n",Er);
19 mprintf("(iv) Terminating resistance should be equal
    to surge impedance of line =%.0f ohms\n",Z1);
20 L=.5*(10^-8);
21 C=10^-12;
22 Z=sqrt(L/C); // surge impedance
23 VR=2*Z*11/((Z1+Z)*sqrt(3));
24 Vrl=(Z-Z1)*11/((Z1+Z)*sqrt(3));
25 PR1=3*VR*VR*1000/(Z);
26 d=abs(Vrl);
27 Prl=3*d*d*1000/Z1;
28 mprintf("(v) Refracted power =%.1f kW\n",PR1);
29 mprintf("Reflected power =%.1f kW\n",Prl);
30 ///Answer don't match exactly due to difference in
    rounding off of digits in between calculations

```

Scilab code Exa 12.2 Find the voltage rise at the junction due to surge

Find the voltage rise at the junction due to surge

```

1 //Find the voltage rise at the junction due to surge
2 clear

```

```

3 clc;
4 Xlc=.3*(10^-3); // inductance of cable (H)
5 Xcc=.4*(10^-6); // capacitance of cable (F)
6 Xlo=1.5*(10^-3); // inductance of overhead line (H)
7 Xco=.012*(10^-6); // capacitance of overhead line (F)
8 Znc=sqrt((Xlc/Xcc));
9 Znl=sqrt((Xlo/Xco));
10 mprintf("Natural impedance of cable=%f ohms \n",
           Znc);
11 mprintf("Natural impedance of overhead line=%f
           ohms \n",Znl);
12 E=2*Znl*15/(353+27);
13 mprintf("voltage rise at the junction due to surge =
           %.2 f kV \n",E);

```

Scilab code Exa 12.3 To find the surge voltages and currents transmitted into branch line

To find the surge voltages and currents transmitted into branch line

```

1 // To find the surge voltages and currents
   transmitted into branch line
2 clear
3 clc;
4 Z1=600;
5 Z2=800;
6 Z3=200;
7 E=100;
8 E1=2*E/(Z1*((1/Z1)+(1/Z2)+(1/Z3)));
9 Iz2=E1*1000/Z2;
10 Iz3=E1*1000/Z3;
11 mprintf("Transmitted voltage =%.2 f kV \n",E1);
12 mprintf("The transmitted current in line Z2=%.2 f
           amps \n",Iz2);

```

```
13 mprintf("The transmitted current in line Z3=%f  
amps \n", Iz3);  
14 //Answer don't match exactly due to difference in  
rounding off of digits in between calculations
```

Scilab code Exa 12.4 Determine the maximum value of transmitted wave

Determine the maximum value of transmitted wave

```
1 //Determine the maximum value of transmitted wave  
2 clear  
3 clc;  
4 Z=350; //surge impedencr (ohms)  
5 C=3000*(10^-12); // earth capacitance(F)  
6 t=2*(10^-6);  
7 E=500;  
8 E1=E*(1-exp((-1*t/(Z*C))));  
9 mprintf("the maximum value of transmitted voltage=%  
.0 f kV \n",E1);
```

Scilab code Exa 12.5 Determine the maximum value of transmitted surge

Determine the maximum value of transmitted surge

```
1 //Determine the maximum value of transmitted surge  
2 clear  
3 clc;  
4 Z=350; //surge impedencr (ohms)  
5 L=800*(10^-6);  
6 t=2*(10^-6);  
7 E=500;  
8 E1=E*(1-exp((-1*t*2*Z/L)));
```

```
9 mprintf("The maximum value of transmitted voltage=%
.1f kV \n",E1);
```

Scilab code Exa 12.6 Determine i the value of the Voltage wave when it has travelled through a distance 50 Km ii Power loss and Heat loss

Determine i the value of the Voltage wave when it has travelled through a distance

```
1 // Determine (i)the value of the Voltage wave when
  it has travelled through a distance 50 Km. (ii)
  Power loss and Heat loss.
2
3 clear
4 clc;
5 eo=50;
6 x=50;
7 R=6;
8 Z=400;
9 G=0;
10 v=3*(10^5);
11 e=2.68;
12 e1=(eo*(e^((-1/2)*R*x/Z)));
13 // answeess does not match due to the difference in
  rounding off of digits.
14 mprintf("(i)the value of the Voltage wave when it
  has travelled through a distance 50 Km=%.\n",e1);
15 P1=e1*e1*1000/400;
16 io=eo*1000/Z;
17 t=x/v;
18 H=-(50*125*400*((e^-.75)-1))/(6*3*10^5)
19 mprintf("(ii)Power loss=%.\n heat loss=%.\n",P1,H);
```

Chapter 13

SYMMETRICAL COMPONENTS AND FAULT CALCULATIONS

Scilab code Exa 13.1 Determine the symmetrical components of voltages

Determine the symmetrical components of voltages

```
1 // Determine the symmetrical components of voltages.  
2 clear  
3 clc;  
4 Va=100*(cosd(0) + %i*sind(0));  
5 Vb=33*(cosd(-100) + %i*sind(-100));  
6 Vc=38*(cosd(176.5) + %i*sind(176.5));  
7 L=1*(cosd(120) + %i*sind(120));  
8 Va1=((Va + L*Vb + (L^2)*Vc))/3;  
9 Va2=((Va + L*Vc + (L^2)*Vb))/3;  
10 Vco=((Va + Vb + Vc))/3;  
11 disp(Va1,"Va1=");  
12 disp(Va2,"Va2=");  
13 disp(Vco,"Vco=");
```

Scilab code Exa 13.2 Find the symmetrical component of currents

Find the symmetrical component of currents

```
1 // Find the symmetrical component of currents
2 clear
3 clc;
4 Ia=500+ %i*150; // Line current in phase a
5 Ib=100- %i*600; // Line current in phase b
6 Ic=-300+ %i*600; // Line current in phase c
7 L=(cosd(120)+ %i*sind(120));
8 Iao=(Ia+Ib+Ic)/3;
9 Ia1=(Ia+Ib*L+(L^2)*Ic)/3;
10 Ia2=(Ia + (L^2)*Ib +(L*Ic))/3;
11 disp(Iao," Iao(amps)=");
12 disp(Ia1," Ia1(amps)=");
13 disp(Ia2," Ia2(amps)");// Answer in the book is not
correct.wrong calculation in the book
```

Scilab code Exa 13.3 Determine the fault current and line to line voltages

Determine the fault current and line to line voltages

```
1 // Determine the fault current and line to line
voltages
2 clear
3 clc;
4 Ea=1;
5 Z1=.25*%i;
6 Z2=.35*%i;
7 Zo=.1*%i;
```

```

8 Ia1=Ea/(Z1+Z2+Zo);
9 L=-.5+%i*.866;
10 Ia2=Ia1;
11 Iao=Ia2;
12 Ia=Ia1+Ia2+Iao;
13 Ib=25*1000/((sqrt(3)*13.2));
14 If=Ib*abs(Ia);
15 Va1=Ea-(Ia1*Z1);
16 Va2=-Ia2*Z2;
17 Va0=-Iao*Zo;
18 Va=Va1+Va2+Va0;
19 Vb1=(L^2)*Va1;
20 Vb2=L*Va2;
21 Vbo=Va0;
22 Vco=Va0;
23 Vc1=L*Va1;
24 Vc2=(L^2)*Va2;
25 Vb=Vb1 + Vb2+Vbo;
26 Vc=Vco+Vc1+Vc2;
27 Vab=Va-Vb;
28 Vac=Va-Vc;
29 Vbc=Vb-Vc;
30 vab=(13.2*abs(Vab))/sqrt(3);
31 vac=(13.2*abs(Vac))/sqrt(3);
32 vbc=(13.2*abs(Vbc))/sqrt(3);
33 disp(If," fault current (amps)=");
34 disp(Vab,"Vab(kV)=");
35 disp(Vac,"Vac(kV)=");
36 disp(Vbc,"Vbc(kV)=");

```

Scilab code Exa 13.4 determine the fault current and line to line voltages at the fault

determine the fault current and line to line voltages at the fault

```
1 //Determine the fault current and line to line
   voltage at the fault .
2 clear
3 clc;
4 Ea=1;
5 L=(cosd(120)+ %i*sind(120));
6 Z1=%i*.25;
7 Z2=%i*.35;
8 Ia1=Ea/(Z1+Z2);
9 Ia2=-Ia1;
10 Iao=0;
11 Ib1=(L^2)*Ia1;
12 Ib2=L*Ia2;
13 Ibo=0;
14 Ib=Ib1+Ib2 +Ibo;
15 Iba=1093;
16 If=Iba*abs(Ib);
17 Va1=Ea-(Ia1*Z1);
18 Va2=-Ia2*Z2;
19 Vao=0;
20 Va=Va1+Va2+Vao;
21 Vb=(L^2)*Va1 + L*Va2;
22 Vc=Vb;
23 Vab=Va-Vb;
24 Vac=Va-Vc;
25 Vbc=Vb-Vc;
26 mprintf(" Fault current =%.2f amps\n",If); //Answer
   don't match due to difference in rounding off of
   digits
27 vab=(abs(Vab)*13.2)/sqrt(3);
28 vbc=(abs(Vbc)*13.2)/sqrt(3);
29 vac=(abs(Vac)*13.2)/sqrt(3);
30 mprintf("Vab=% .2f kV\n",vab);
```

```
31 mprintf("Vac=%f kV\n",vac);
32 mprintf("Vbc=%f kV\n",vbc);
```

Scilab code Exa 13.5 determine the fault current and line to line voltages at the fault

determine the fault current and line to line voltages at the fault

```
1 // determine the fault current and line to line
   voltages at the fault
2 clear
3 clc;
4 Ea=1+ 0*i;
5 Zo=%i*.1;
6 Z1=%i*.25;
7 Z2=%i*.35;
8 Ia1=Ea/(Z1+(Zo*Z2/(Zo+Z2)));
9 Va1=Ea-Ia1*Z1;
10 Va2=Va1;
11 Vao=Va2;
12 Ia2=-Va2/Z2;
13 Iao=-Vao/Zo;
14 I=Ia2+Iao;
15 If=3*Iao; // fault current
16 Ib=1093; // base current
17 Ifl=abs(If*Ib);
18 disp(Ifl,"Fault current (amps) ="); //Answer don't
   match due to difference in rounding off of digits
19 Va=3*Va1
20 Vb=0;
21 Vc=0;
22 Vab=abs(Va)*13.2/sqrt(3);
23 Vac=abs(Va)*13.2/sqrt(3);
24 Vbc=abs(Vb)*13.2/sqrt(3);
25 mprintf("Vab=%f kV\n",Vab);
```

```
26 mprintf("Vac=%f kV\n", Vac);
27 mprintf("Vbc=%f kV\n", Vbc);
```

Scilab code Exa 13.6 Determine the fault current when i LG ii LL iii LLG fault takes place at P

Determine the fault current when i LG ii LL iii LLG fault takes place at P

```
1 //Determine the fault current when (i)L-G (ii)L-L (iii)L-L-G fault takes place at P.
2 clear
3 clc;
4 Vbl=13.8*115/13.2; // base voltage on the line side
of transformer(kV)
5 Vbm=120*13.2/115; // base voltage on the motor side
of transformer(kV)
6 Xt=10*((13.2/13.8)^2)*30/35; // percent reactance of
transformer
7 Xm=20*((12.5/13.8)^2)*30/20; // percent reactance of
motor
8 Xl=80*30*100/(120*120); //percent reactance of line
9 Xn=2*3*30*100/(13.8*13.8); // neutral reactance
10 Xz=200*30*100/(120*120);
11 Zn=%i*.146; // negative sequence impedance
12 Zo=.06767; // zero sequence impedance
13 Z=%i*.3596; //total impedance
14 Ia1=1/Z;
15 Ia2=Ia1;
16 Iao=Ia2;
17 If1=3*Ia1;
18 Ib=30*1000/(\sqrt(3)*13.8);
19 Ibl=30*1000/(\sqrt(3)*120);
20 Ifc=Ibl*abs(If1);
21 Z1=%i*.146;
22 Z2=Z1;
```

```

23 IA1=1/(Z1+Z2)
24 IA2=-IA1
25 L=(cosd(120)+ %i*sind(120));
26 IAo=0;
27 IB=(L^2)*IA1 + L*IA2;
28 IC=-IB;
29 IF=abs(IB)*Ibl;
30 Zo=%i*.06767;
31 ia1=1/(Z1+(Zo*Z2/(Zo+Z2)));
32 ia2=ia1*Zo/(Z2+Zo);
33 iao=%i*3.553;
34 If2=3*ia0;
35 IF2=abs(If2*Ibl);
36 mprintf(" Fault Current (i)L-G fault , If=%.0f amps\n
           ", Ifc);
37 mprintf("(ii)L-L fault , If=%.1f amps\n", IF);
38 mprintf("(iii)L-L-G, If =%.0f amps\n", IF2);

```

Scilab code Exa 13.8 Determine the percent increase of busbar voltage

Determine the percent increase of busbar voltage

```

1 //Determine the percent increase of busbar voltage
2 clear
3 clc;
4 vx=3; // percent reactance of the series element
5 sinr=.6;
6 V=vx*sinr;
7 mprintf(" Percent drop of volts=% .1f percent\n",V);

```

Scilab code Exa 13.9 Determine the short circuit capacity of the breaker

Determine the short circuit capacity of the breaker

```
1 //Determine the short circuit capacity of the  
    breaker  
2 clear  
3 clc;  
4 Sb=8; // Base MVA  
5 Zeq=(%i*.15)*(%i*.315)/(%i*.465);  
6 Scc=abs(Sb/Zeq);  
7 mprintf("short circuit capacity=%f MVA\n",Scc);
```

Scilab code Exa 13.10 To determine the short circuit capacity of each station

To determine the short circuit capacity of each station

```
1 // To determine the short circuit capacity of each  
    station  
2 clear  
3 clc;  
4 X=1200*100/800; // percent reactance of other  
    generating station  
5 Xc=.5*1200/(11*11);  
6 Sc=1200*100/86.59; // short circuit MVA of the bus  
7 Xf=119.84; // equivalent fault impedance between F  
    and neutral bus  
8 MVA=1200*100/Xf;  
9 mprintf("short circuit capacity of each station=%f  
    MVA\n",MVA);
```

Scilab code Exa 13.11 Determine the Fault MVA

Determine the Fault MVA

```

1 // Determine the Fault MVA
2 clear
3 clc;
4 Sb=100; // base power (MVA)
5 SC=Sb/.14;
6 mprintf("S.C. MVA =%.2f MVA\n",SC);

```

Scilab code Exa 13.12 To Determine the subtransient current in the alternator motor and the fault

To Determine the subtransient current in the alternator motor and the fault

```

1 // To Determine the subtransient current in the
   alternator , motor and the fault
2 clear
3 clc;
4 Ib=50*1000/(sqrt(3)*13.2); // base current (amps.)
5 Vf=12.5/13.5; // the Prefault Voltage (p.u)
6 Xf=(%i*.3)*(%i*.2)/(%i*.5); // Fault impedance(p.u)
7 If=.9469/(Xf); //Fault current (p.u)
8 Ifl=30*1000/((sqrt(3)*12.5*.8)); //full load current
   (amps)
9 Il=1732*(cosd(36.8)+%i*sind(36.8))/2186; //load
   current(p.u)
10 Ifm=3*(If)/5; // fault current supplied by motor (p.u
    )
11 Ifg=2*(If)/5; // fault current supplied by generator
    (p.u)
12 Ig=abs(Ifg +Il); //Net current supplied by generator
    during fault(p.u)
13 Im=abs(Ifm-Il); //Net current supplied by motor
    during fault(p.u)
14 Igf=Ig*2186;
15 Imf=Im*2186;
16 Ifc=2186*If;

```

```

17 mprintf("Fault current from the generator =%.3f amps
\n", Igf);
18 mprintf("Fault current from the motor =%.3f amps\n",
Imf);
19 disp(Ifc,"Fault current (amps)=");

```

Scilab code Exa 13.13 To Determine the reactance of the reactor to prevent the breakers being overloaded

To Determine the reactance of the reactor to prevent the breakers being overloaded

```

1 //To Determine the reactance of the reactor to
   prevent the breakers being overloaded
2 clear
3 clc;
4 Sb=75; // Base MVA
5 Xpu=.15*Sb/15;// p.u reactance of the generator
6 Xt=-%i*.08; //p.u reactance of the transformer
7 X=9.75/112;
8 Xa=X*33*33/75;
9 mprintf("the reactance of the reactor =%.3f ohms\n",
Xa);

```

Scilab code Exa 13.14 Determine the subtransient currents in all phases of machine1 the fault current and the voltages of machine 1 and voltage at the fault point

Determine the subtransient currents in all phases of machine1 the fault current and

```

1 // Determine the subtransient currents in all phases
   of machine-1 , the fault current and the
   voltages of machine 1 and voltage at the fault
   point.

```

```

2 clear
3 clc;
4 Z1eq= %i*((8+5)*(8+5+12))/(100*(13+25));
5 Z2eq=Z1eq;
6 Zoeq=%i*(5*45)*(10^-2)/(5+45);
7 Ea=1;
8 Ia1=Ea/(Z1eq+ ((Zoeq*Z2eq)/(Zoeq+Z2eq)));
9 Ia2=(-Ia1*Zoeq)/(Zoeq+Z2eq);
10 Iao=(-Ia1*Z2eq)/(Zoeq+Z2eq);
11 Va1=Ea-(Ia1*Z1eq);
12 Va2=-Ia2*Z2eq;
13 Vao=Va2;
14 Ia=0;
15 Ib=(-.5 - %i*.866)*Ia1 + ((-.5 + %i*.866)*Ia2) + Iao
    ;
16 Ic=(-.5 + %i*.866)*Ia1 + (-.5 - %i*.866)*Ia2 + Iao;
17 ia1=Ia1*25/38;
18 IA1=%i*ia1;
19 ia2=Ia2*25/38;
20 IA2=-%i*ia2;
21 IA=IA1 + IA2;
22 IB=IA1*(-.5 - %i*.866) + IA2*(-.5 + %i*.866);
23 IC=IA1*(-.5 + %i*.866) + IA2*(-.5 - %i*.866);
24 Va=Va1+Va2+Vao;
25 Vb=0;
26 Vc=0;
27 Vab=.2564-Vb;
28 Vbc=Vb-Vc;
29 Vca=Vc-.2564;
30 VA1=Ea-IA1*(%i*.05);
31 VA2=-IA2*(%i*.05);
32 VA=VA1+VA2;
33 VB=(((-.5 - %i*.866)*VA1) +((-.5 + %i*.866)*VA2));
34 VC=VA1*(-.5 + %i*.866) + VA2*(-.5 - %i*.866);
35 VAB=VA-VB;
36 VBC=VB-VC;
37 VCA=VC-VA;
38 //Answers don't match due to difference in rounding

```

```

        off of digits
39 disp(Ia," fault currents ,Ia=" );
40 disp(Ib," Ib=" );
41 disp(Ic," Ic=" ); // Calculation in book is wrong.
42 disp(IA," IA=" );
43 disp(IB," IB" );
44 disp(IC," IC" );
45 disp(" Voltages at fault point");
46 disp(Vab,"Vab(p.u)=" );
47 disp(Vbc,"Vbc(p.u)=" );
48 disp(Vca,"Vca(p.u)=" );
49 disp(VAB,"VAB=" );
50 disp(VBC,"VBC=" );
51 disp(VCA,"VCA=" );

```

Scilab code Exa 13.15 To determine the i pre fault current in line a ii the subtransient current in pu iii the subtransient current in each phase of generator in pu

To determine the i pre fault current in line a ii the subtransient current in pu

```

1 // To determine the (i) pre- fault current in line a
    (ii) the subtransient current in p.u (iii) the
    subtransient current in each phase of generator
    in p.u
2 clear
3 clc;
4 Ia1=-.8 -%i*2.6 + .8 -%i*.4;
5 Ia2=-%i*3;
6 Iao=-%i*3;
7 A=-.8 -%i*2.6 + .8 +%i*2;
8 a=.8;
9 b=.6;
10 Ipf=a + %i*b;
11 Isfc=3*Ia1;
```

```

12 iA1=.8- %i*.4;
13 iA2=-%i*1;
14 iAo=0;
15 IA1=%i*iA1;
16 IA2=-%i*iA2;
17 IA=IA1 + IA2;
18 L=cosd(120)+ %i*sind(120);
19 IB=(L^2)*IA1 + IA2*L;
20 IC=(L^2)*IA2 + IA1*L;
21 disp(Ipf,"(i) pre-fault current in line a=");
22 disp(Isfc,"(ii) the subtransient fault current in p.u=");
23 disp(IA,"IA=");
24 disp(IB,"IB=");
25 disp(IC,"IC=");

```

Scilab code Exa 13.16 Determine the short circuit MVA of the transformer

Determine the short circuit MVA of the transformer

```

1 // Determine the short circuit MVA of the
   transformer
2 clear
3 clc;
4 S.C.MVA=.5/.05;
5 mprintf("S.C.MVA=%f MVA",S.C.MVA);

```

Scilab code Exa 13.17 To determine the line voltages and currents in per unit on delta side of the transformer

To determine the line voltages and currents in per unit on delta side of the trans

```

1 //To determine the line voltages and currents in per
   unit on delta side of the transformer
2 clear
3 clc;
4 vab=2000;
5 vbc=2800;
6 vca=2500;
7 vb=2500;// base voltage (V)
8 Vab=vab/vb;// per unit voltages
9 Vbc=vbc/vb;
10 Vca=vca/vb;
11 a=acosd(((1.12^2)-((.8^2)+1))/(2*.8));
12 b=acosd(((.8^2)-((1.12^2)+1))/(2*1.12));
13 Vlab=Vab*(cosd(76.06)+%i*sind(76.06));// line
   voltage
14 Vlca=Vca*(cosd(180)+%i*sind(180));// line voltage
15 Vlbc=Vbc*(cosd(-43.9)+%i*sind(-43.9));// line
   voltage
16 L=1*(cosd(120) + %i*sind(120));
17 Vab1=(Vlab +(L*Vlbc) + ((L^2)*Vlca))/3;// 
   symmetrical component of line voltage
18 Vab2=(Vlab +(L*Vlca) + ((L^2)*Vlbc))/3;// 
   symmetrical component of line voltage
19 Vabo=0;// symmetrical component of line voltage
20 Van1=Vab1*(cosd(-30)+ %i*sind(-30));
21 Van2=Vab2*(cosd(30)+ %i*sind(30));
22 Ia1=Van1/(1*(cosd(0) + %i*sind(0)));
23 Ia2=Van2/(1*(cosd(0) + %i*sind(0)));
24 VA1=-%i*Van1;
25 VA2=%i*Van2;
26 VA=VA1+ VA2;
27 VB1=(L^2)*VA1;
28 VB2=(L)*VA2;
29 VB=VB1 + VB2;
30 VC2=(L^2)*VA2;
31 VC1=(L)*VA1;
32 VC=VC1 + VC2;
33 VAB=VA-VB;

```

```
34 VBC=VB-VC;  
35 VCA=VC-VA;  
36 IA=VA;  
37 IB=VB;  
38 IC=VC;  
39 phase_IA=atand(imag(IA)/real(IA));  
40 phase_IB=atand(imag(IB)/real(IB));  
41 phase_IC=atand(imag(IC)/real(IC));  
42 disp(VAB,"VAB(p.u)=");  
43 disp(VBC,"VBC(p.u)=");  
44 disp(VCA,"VCA(p.u)=");  
45 mprintf("IA(p.u)=%f at an angle of %f\n",abs(IA),  
phase_IA);  
46 mprintf("IB(p.u)=%f at an angle of %f\n",abs(IB),  
phase_IB);  
47 mprintf("IC(p.u)=%f at an angle of %f",abs(IC),  
phase_IC);
```

Chapter 14

PROTECTIVE RELAYS

Scilab code Exa 14.1 To determine the time of operation of relay

To determine the time of operation of relay

```
1 // To determine the time of operation of relay .
2 clear
3 clc;
4 If=4000; // fault current
5 I=5*1.25; // operating current of relay
6 CT=400/5; // CT ratio
7 PSM=If/(I*CT); // plug setting multiplier
8 mprintf("PSM=%f\n",PSM);
9 mprintf("operating time for PSM=8 is 3.2 sec.\n");
10 mprintf("actual operating time = 1.92 sec.");
```

Scilab code Exa 14.2 To determine the phase shifting network to be used

To determine the phase shifting network to be used

```

1 // To determine the phase shifting network to be
   used .
2 clear
3 clc;
4 Z=1000*(cosd(60) + %i*sind(60)); //impedence
5 X=tand(50)*1000*cosd(60);
6 Xl=1000*sind(60);
7 Xc=Xl-X;
8 C=1000000/(314*Xc);
9 //Answers don't match due to difference in rounding
   off of digits
10 disp(X,"X=");
11 disp(Xc,"Xc=");
12 disp(C,"C(micro farads)=");

```

Scilab code Exa 14.3 To provide time current grading

To provide time current grading

```

1 //To provide time current grading .
2 clear
3 clc;
4 Isec1=4000/40; // secondary current (amps)
5 PSM=100/5; // PSM if 100% setting is used
6 Isec2=4000/40;
7 PSM2=100/6.25; //PSM if setting used is 125%
8 TMSb=.72/2.5;
9 PSM1=5000/(6.25*40);
10 to=2.2;
11 tb=to*TMSb;
12 PSMa=5000/(6.25*80);
13 TMS=1.138/3;
14 PSMa1=6000/(6.25*80);
15 ta=(2.6*.379);

```

```
16 mprintf("Actual operating time of realy at b=%.3f  
sec. \n",tb);  
17 mprintf("Actual operating time of realy at a=%.3f  
sec. \n",ta);
```

Scilab code Exa 14.4 To determine the proportion of the winding which remains unprotected against earth fault

To determine the proportion of the winding which remains unprotected against earth

```
1 // To determine the proportion of the winding which  
   remains unprotected against earth fault.  
2 clear  
3 clc;  
4 Vph=6600/(sqrt(3));  
5 Ifull=5000/(sqrt(3)*6.6);  
6 Ib=Ifull*.25;  
7 x=Ib*800/Vph;  
8 mprintf("percent of the winding remains unprotected=%  
%.2f \n",x);
```

Scilab code Exa 14.5 To determine i percent winding which remains unprotected ii min value of earthing resistance required to protect 80 percent of winding

To determine i percent winding which remains unprotected ii min value of earthing

```
1 // To determine (i) % winding which remains  
   unprotected (ii)min. value of earthing resistance  
   required to protect 80% of winding  
2 clear  
3 clc;
```

```
4 Iph=10000/sqrt(3); // phase voltage of alternator(V)
5 x=1.8*100*10*1000/(5*Iph);
6 mprintf("(i) percent winding which remains
unprotected=%f\n",x);
7 Ip=Iph*.2;
8 R=1.8*1000/(5*Ip);
9 mprintf("(ii) minimum value of earthing resistance
required to protect 80 percent of winding =%f
ohms \n",R)
```

Scilab code Exa 14.6 To determine whether relay will operate or not

To determine whether relay will operate or not

```
1 //To determine whether relay will operate or not.
2 clear
3 clc;
4 Ic=360-320; // the difference current (amp)
5 Io=40*5/400;
6 Avg=(360+320)/2; // average sum of two currents
7 Iavg=340*5/400;
8 Ioc=.1*Iavg + .2;
9 mprintf("operating current=%f amp. \n",Ioc);
10 mprintf("since current through operating coil is %
.3 f amp. \n ",Io);
11 mprintf("therefore Relay will not operate ");
```

Scilab code Exa 14.7 To determine the ratio of CT on HV side

To determine the ratio of CT on HV side

```
1 // To determine the ratio of CT on HV side
2 clear
3 clc;
4 Il=400*6.6/33; // line current on star side of PT(
    amps)
5 Ic=5/sqrt(3); // current in CT secondary
6 mprintf(" the CT ratio on HT will be %d : %.3f",Il,
    Ic);
```

Scilab code Exa 14.8 To determine the number of turns each current transformer should have

To determine the number of turns each current transformer should have

```
1 // To determine the number of turns each current
    transformer should have .
2 clear
3 clc;
4 Il=10000/((sqrt(3))*132);
5 ILV=10000/((sqrt(3))*6.6);
6 a=5/sqrt(3);
7 mprintf("ratio of CT on LV side is %.3f : %.3f\n",
    ILV,a);
8 mprintf("ratio of CT on HT side is %.3f : %d",Il,5);
```

Scilab code Exa 14.9 To determine the R1 R2 and C also The potential across relays

To determine the R1 R2 and C also The potential across relays

```
1 //To determine the R1, R2 and C. also The potential
    across relays
```

```

2 clear
3 clc;
4 Vs=110;
5 I=1;
6 R2=Vs/((3-%i*sqrt(3))*I);
7 c=abs(R2);
8 mprintf("R2=%f ohms\n",c);
9 R1=2*c;
10 d=abs(R1);
11 C=(10^6)/( .866*d*314);
12 mprintf("R1=%f ohms\n",R1);
13 mprintf("C=%f micro farads\n",C);
14 Vt=d*(-.5 - %i*.866) + (c - %i*55 );
15 disp(Vt," Voltage across the terminals of the relay
will be (V)=");

```

Scilab code Exa 14.10 To determine the kneepoint voltage and cross section of core

To determine the kneepoint voltage and cross section of core

```

1 // To determine the kneepoint voltage and cross
   section of core
2 clear
3 clc;
4 Ic=5*.25; // operating current(amp)
5 Vsec=5/1.25; // secondary voltage(V)
6 Bm=1.4;
7 f=50;
8 N=50;
9 V=15*Vsec;
10 A=60/(4.44*Bm*f*N);
11 mprintf(" the knee point must be slightly higher
           than =%3f V\n",V);
12 mprintf(" area of cross section=%f m_2\n",A);

```

Scilab code Exa 14.11 To determine the VA output of CT

To determine the VA output of CT

```
1 // To determine the VA output of CT .
2 clear
3 clc;
4 o.p=5*5*(.1+.1) +5;
5 mprintf(" VA output of CT =%.0f VA\n ",o.p);
```

Chapter 15

CIRCUIT BREAKERS

Scilab code Exa 15.1 To determine the voltage appearing across the pole of CB also determine the value of resistance to be used across contacts

To determine the voltage appearing across the pole of CB also determine the value

```
1 // To determine the voltage appearing across the
   pole of C.B. also determine the value of
   resistance to be used across contacts
2 clear
3 clc;
4 i=5;
5 L=5*(10^6);
6 C=.01;
7 e=i*sqrt(L/C);
8 mprintf("the voltage appearing across the pole of C.
   B.=%.0 f V\n",e);
9 R=.5*sqrt(L/C);
10 mprintf("the value of resistance to be used across
   contacts , R=%.0 f ohms\n",R);
```

Scilab code Exa 15.2 To determine the rate of rise of restriking voltage

To determine the rate of rise of restriking voltage

```
1 // To determine the rate of rise of restriking  
    voltage  
2 clear  
3 clc;  
4 Vnl=132*sqrt(2)/sqrt(3); //peak value of peak to  
    neutral voltage(kV)  
5 Vr1=Vnl*.95; //recovery voltage (kV)  
6 Vr=102.4*.916; // active recovery voltage(kV)  
7 Vrmax=2*Vr;  
8 fn=16*(10^3);  
9 t=1/(2*fn);  
10 RRRV=Vrmax*(10^-6)/t;  
11 mprintf(" rate of rise of restriking voltage , RRRV=%  
    .0 f kV/micro-sec" ,RRRV);
```

Scilab code Exa 15.3 To Determine the average rate of rise of restriking voltage

To Determine the average rate of rise of restriking voltage

```
1 // To Determine the average rate of rise of  
    restriking voltage  
2 clear  
3 clc;  
4Vm=132*sqrt(2)/sqrt(3);  
5 K1=.9;  
6 K2=1.5  
7 K=K1*K2;  
8 sinq=.92;  
9 Vr=K*Vm*sinq;  
10 fn=16*(10^3);
```

```
11 RRRV=2*Vr*(10^-6)*fn*2;
12 mprintf(" average rate of rise of restriking voltage ,
RRRV=%f kV/micro-sec\n",RRRV);
```

Scilab code Exa 15.4 To determine the rated normal current breaking current making current and short time rating current

To determine the rated normal current breaking current making current and short time rating current

```
1 // To determine the rated normal current , breaking
   current , making current and short time rating (
   current)
2 clear
3 clc;
4 In=1500;
5 mprintf(" rated normal current=%f amps\n",In);
6 Ib=2000/(sqrt(3)*33);
7 mprintf(" breaking current=%f KA\n",Ib);
8 Im=2.55*Ib;
9 mprintf(" making current =%f kA\n",Im);
10 Is=Ib;
11 mprintf(" short time rating for 3 sec=%f kA\n",Is)
;
```

Scilab code Exa 15.5 TO Determine i sustained short circuit current in the breaker ii initial symmetrical rms current in the breaker iii maximum possible dc component of the short circuit current in the breaker iv momentary current rating of the breaker v the current

TO Determine i sustained short circuit current in the breaker ii initial symmetrical rms current in the breaker iii maximum possible dc component of the short circuit current in the breaker iv momentary current rating of the breaker v the current

```

1 //TO Determine (i)sustained short circuit current in
   the breaker (ii)initial symmetrical r.m.s
   current in the breaker (iii)maximum possible d.c
   component of the short circuit current in the
   breaker (iv)momentary current rating of the
   breaker (v)the current to be interrupted by the
   breaker (vi)the interupting kVA.
2 clear
3 clc;
4 MVA=10;
5 Is=MVA*1000/(sqrt(3)*13.8);
6 mprintf("(i)sustained short circuit current in the
   breaker =%.0f amps\n",Is);
7 MVA1=100;
8 Isc=MVA1*1000/(sqrt(3)*13.8);
9 mprintf("(ii)initial symmetrical r.m.s current in
   the breaker r.m.s=% .0f amps\n",Isc);
10 Im=sqrt(2)*Isc;
11 mprintf("(iii)maximum possible d.c component of the
   short circuit current in the breaker =%.0f amps\n",
   ",Im);
12 Im2=1.6*Isc;
13 mprintf("(iv)momentary current rating of the breaker
   =%.0f amps\n",Im2);
14 Ib=1.2*Isc;
15 mprintf("(v)the current to be interrupted by the
   breaker =%.0f amps\n",Ib);
16 KVA=sqrt(3)*13.8*5016;
17 mprintf("(vi)the interupting =%.0f KVA\n",KVA);
18 //Answers don't match due to difference in rounding
   off of digits

```

Chapter 17

POWER SYSTEM SYNCHRONOUS STABILITY

Scilab code Exa 17.1 To determine the acceleration Also determine the change in torque angle and rpmat the end of 15 cycles

To determine the acceleration Also determine the change in torque angle and rpmat

```
1 // To determine the acceleration . Also determine
   the change in torque angle and r.p.mat the end of
   15 cycles
2 clear
3 clc;
4 H=9;
5 G=20; // machine Rating (MVA)
6 KE=H*G;
7 mprintf("(a)K.E stored in the rotor =%.0f MJ\n",KE);
8 Pi=25000*.735;
9 PG=15000;
10 Pa=(Pi-PG)/(1000);
11 f=50;
12 M=G*H/(%pi*f);
13 a=Pa/M;
14 mprintf("(b) The accelerating power =%.3f MW\n",Pa);
```

```

15 mprintf(" Acceleration =%.3f rad/sec_2\n",a);
16 t=15/50;
17 del=sqrt(5.89)*t/2;
18 Del=del^2;
19 k=2.425*sqrt(Del)*60/4*pi;
20 speed=1504.2;
21 mprintf("(c) Rotor speed at the end of 15 cycles =%.1
           f r.p.m",speed);

```

Scilab code Exa 17.2 To determine the frequency of natural oscillations if the generator is loaded to i 60 Percent and ii 75 percent of its maximum power transfer capacity

To determine the frequency of natural oscillations if the generator is loaded to i

```

1 // To determine the frequency of natural
   oscillations if the generator is loaded to (i)60%
   and (ii)75% of its maximum power transfer
   capacity
2 clear
3 clc;
4 V1=1.1;
5 V2=1;
6 X=.5;
7 cosdo=.8;
8 G=1;
9 H=3;
10 f=50;
11 M=G*H/(%pi*f);
12 dPe=V1*V2*cosdo/X;
13 fn=((dPe)/M)^.5)/6.28;
14 sind0=.75;
15 d0=asind(sind0);
16 dPe2=V1*V2*cosd(d0)/X;
17 fn2=((dPe2)/M)^.5)/6.28;

```

```
18 mprintf("( i ) fn=%f Hz\n",fn);
19 mprintf("( i ) fn (Hz)=%f Hz",fn2);
```

Scilab code Exa 17.3 To calculate the maximum value of d during the swinging of the rotor around its new equilibrium position

To calculate the maximum value of d during the swinging of the rotor around its ne

```
1 //To calculate the maximum value of d during the
   swinging of the rotor around its new equilibrium
   position
2 clc
3 clear
4 a=.25; //sindo=.25
5 do=asind(a); //
6 b=.5 //sindc=.5
7 dc=asind(b);
8 c=cosd(do)+.5*do*%pi/180;
9 dm=dc;
10 e=1;
11 while(e>.0001)
12     dm=dm+.1;
13     e=abs(c-((.5*dm*%pi)/180)+cosd(dm)));
14 end
15 printf("dm approximately found to be %d degree",dm);
```

Scilab code Exa 17.4 To calculate the critical clearing angle for the condition described

To calculate the critical clearing angle for the condition described

```

1 // To calculate the critical clearing angle for the
   condition described.
2 clear
3 clc;
4 sindo=.5;
5 d0=asind(sindo)*%pi/180;
6 r1=.2;
7 r2=.75;
8 sindm=.5/.75;
9 d=asind(sindm);
10 cosdm=cosd(d);
11 dm=%pi*(180-(asind(sindm)))/180;
12 Dc=((.5*(dm-d0))-(r2*cosdm)-(r1*cosd(d0)))/(r2-r1);
13 dc=acosd(Dc); // critical angle
14 mprintf("The critical clearing angle is given by=%
.2f degrees",dc); //Answers don't match due to
difference in rounding off of digits

```

Scilab code Exa 17.5 To calculate the critical clearing angle for the generator for a 3phase fault

To calculate the critical clearing angle for the generator for a 3phase fault

```

1 // To calculate the critical clearing angle for the
   generator for a 3-phase fault
2 clear
3 clc;
4 ZA=.375;
5 ZB=.35;
6 ZC=.0545;
7 ZAB=((ZA*ZB)+(ZB*ZC)+(ZC*ZA))/ZC; //Reactance between
   the generator and infinite bus during the fault (p.u)
8 Zgbf=%i*.3+ %i*(.55/2) +%i*.15; //Reactance between
   the generator and infinite bus before the fault (p.u)

```

```

9 Zgb=%i*.3+ %i*(.55) +%i*.15; //Reactance between the
   generator and infinite bus after the fault is
   cleared (p.u)
10 Pmaxo=1.2*1/abs(Zgbf); // Maximum power output Before
    the fault (p.u)
11 Pmax1=1.2*1/abs(ZAB); // Maximum power output during
    the fault (p.u)
12 Pmax2=1.2*1/abs(Zgb); // Maximum power output after
    the fault (p.u)
13 r1=Pmax1/Pmaxo;
14 r2=Pmax2/Pmaxo;
15 Ps=1;
16 sindo=Ps/Pmaxo;
17 do=asind(sindo);
18 d0=asind(sindo)*%pi/180;
19 sindm=1/Pmax2;
20 cosdm=cosd(asind(sindm));
21 Dm=%pi*(180-(asind(sindm)))/180;
22 Dc=((sindo*(Dm-d0)-(r2*cosdm)-(r1*cosd(do)))/(r2-
   r1);
23 dc=acosd(Dc); // critical angle
24 mprintf("The critical clearing angle is given by= %
   .1f ",dc);

```

Scilab code Exa 17.6 determine the critical clearing angle

determine the critical clearing angle

```

1 // (A) determine the critical clearing angle
2 clear
3 clc;
4 Pm=%i*.12 + %i*.035 + ((%i*.25*%i*.3)/%i*.55);
5 Pm1=0;
6 Pm2=1.1*1/.405;
7 r1=0;

```

```

8 r2=2.716/3.775;
9 d0=(asind(1/3.775));
10 dM=(180-asind(1/2.716));
11 do=d0*pi/180;
12 dm=dM*pi/180;
13 dc=acosd(((dm-do)*sind(d0))-(r1*cosd(d0))+(r2*cosd(
    dM)))/(r2-r1));
14 mprintf("dc=%f",dc);

```

Scilab code Exa 17.7 To determine the centre and radius for the pull out curve ans also minimum output vars when the output powers are i 0 ii 25pu iii 5pu

To determine the centre and radius for the pull out curve ans also minimum output

```

1 // To determine the centre and radius for the pull
   out curve ans also minimum output vars when the
   output powers are (i)0 (ii).25p.u (iii) .5p.u
2 clear
3 clc;
4 Pc=0;
5 V=.98;
6 Qc=V^2*((1/.4)-(1/1.1))/2;
7 R=V^2*((1/.4)+(1/1.1))/2;
8 Q=-(.98^2*((1.1-.4)/.44)/2) + (.98^2)*1.5/(2*.44);
9 mprintf("(i)Q=%f MVAr\n",abs(Q)*100);
10 P=.25;
11 Q2=-((1.637^2)-(25^2))^5 + .7639;
12 mprintf("(ii)Q=%f p.u\n",Q2);
13 Q3=-((1.637^2)-(5^2))^5 + .7639;
14 mprintf("(iii)Q=%f p.u",Q3);

```

Scilab code Exa 17.8 Compute the prefault faulted and post fault reduced Y matrices

Compute the prefault faulted and post fault reduced Y matrices

```
1 // Compute the prefault , faulted and post fault
   reduced Y matrices
2 clear
3 clc;
4 y=[-%i*5 0 %i*5 ; 0 -%i*5 %i*5;%i*5 %i*5 -%i*10 ];
5 YAA=[-%i*5 0;0 -%i*5];
6 YAB=[%i*5;%i*5];
7 YBA=[%i*5 %i*5];
8 YBB=[%i*10];
9 Y=YAA-YAB*(inv(YBB))*YBA;
10 Yfull=[-%i*5 0 %i*5;0 -%i*7.5 %i*2.5;%i*5 %i*2.5 -%i
    *12.5];
11 disp(Yfull,"(i) faulted case , full matrix (admittance)
    =");
12 Y=[-%i*3 %i*1;%i*1 -%i*7];
13 disp(Y,"(ii) Pre-fault case , reduced admittance
    matrix=");
14 Y=[-%i*5 0 %i*5;0 -%i*2.5 %i*2.5;%i*5 %i*2.5 -%i
    *7.5];
15 disp(Y,"(iii) Post-fault case , full matrix (admittance
    )=");
16 Y=[-%i*1.667 %i*1.667;%i*1.667 -%i*1.667];
17 disp(Y," reduced admittance matrix");
```

Scilab code Exa 17.9 Determine the reduced admittance matrices for pre-fault fault and post fault conditions and determine the power angle characteristics for three conditions

Determine the reduced admittance matrices for prefault fault and post fault condit

```

1 // Determine the reduced admittance matrices for
   fault and post fault conditions and
   determine the power angle characterstics for
   three conditions .
2 clear
3 clc;
4 Y=[-%i*8.33 0 %i*8.33 0;0 -%i*28.57 0 %i*28.75;%i
   *8.33 0 -%i*15.67 %i*7.33;0 %i*28.57 %i*7.33 -%i
   *35.9];
5 YBB=[-%i*15.67 %i*7.33;%i*7.33 -%i*35.9];
6 YAA=[-%i*8.33 0;0 -%i*28.57];
7 YAB=[%i*8.33 0;0 %i*28.57];
8 YBA=YAB;
9 Y=YAA-(YAB*(inv(YBB))*YBA);
10 Y1=([-%i*8.33 0;0 -%i*28.57])-(([0;(%i*28.57/-%i
    *35.9)]*[0 %i*28.57]));
11 disp(Y1,"Reduced admittance matrix during fault=");
12 Yfull=[-%i*8.33 0 %i*8.33 0;0 -%i*28.57 0 %i*28.75;
   %i*8.33 0 -%i*12.33 %i*4;0 %i*28.57 %i*4 -%i
   *32.57];
13 YBB=[-%i*12.33 %i*4;%i*4 -%i*32.57];
14 Y=YAA-(YAB*(inv(YBB))*YBA);
15 disp(Y,"(i) Post fault condition ,reduced matrix=");
16 Y12=Y(1,2);
17 E1=1.1;
18 E2=1;
19 printf("\n Power angle characterstics , Pe= %fsind",
   abs(Y12)*E1*E2);

```

Scilab code Exa 17.10 To Determine the rotor angle and angular frequency using runga kutta and eulers modified method

To Determine the rotor angle and angular frequency using runga kutta and eulers mo

```

1 // To Determine the rotor angle and angular
   frequency using runga kutta and euler 's modified
   method
2
3 clc
4 clear
5 Pm=3;
6 r1Pm=1.2;
7 r2Pm=2;
8 H=3;
9 f=60;
10 Dt=.02;
11 Pe=1.5;
12 Do=asind(1.5/3);
13 do=Do/57.33;
14 wo=0;
15 d=0;
16 K10=0;
17 l10=62.83*(1.5-1.2*sin(do))*.02;
18 K20=(377.5574-376.992)*.02;
19 l20=62.83*(1.5-1.2*sin(do))*.02;
20 K30=(377.5574-376.992)*.02;
21 l30=62.83*(1.5-1.2*sin(.5296547))*.02;
22 K40=l30*0.02;
23 l40=62.83*(1.5-1.2*sin(.5353094))*.02;
24 d1=.53528;
25 Dwo=(3*1.13094+2*1.123045+1.115699)/6;
26 w1=wo+Dwo;
27 d1=.53528;
28 mprintf ("Runga-Kutta method-\n")
29 mprintf ("w1=% .6f \ nd1=% .5f \ n" ,w1 ,d1 );
30 d7=1.026;
31 w7=6.501;
32 wp=376.992+6.501;
33 K17=(wp-376.992)*0.02;
34 l17=62.83*(1.5-1.2*sin(1.026))*.02;
35 K27=(6.501+.297638)*0.02;
36 l27=62.83*(1.5-1.2*sin(1.09101))*.02;

```

```

37 K37=(6.501+.2736169)*0.02;
38 137=62.83*(1.5-1.2*sin(1.0939863))*.02;
39 K47=(6.501+.545168)*0.02;
40 147=62.83*(1.5-1.2*sin(1.16149))*.02;
41 Dd7=(K17+2*K27+2*K37+K47)/6;
42 d8=d7+Dd7;
43 Dw7=(117+2*127+2*137+147)/6;
44 w8=w7+Dw7;
45 mprintf("d8=% .5 f rad.\nw8=% .4 f rad/sec\n\n",d8,w8)
46 mprintf(" using Euler 's Modified Method-\n");
47 d0=0;
48 d10=.524;
49 w=62.83*(1.5-1.2*sin(.524));
50 d11=d10+0;
51 w11=w*.02;
52 d=1.13094;
53 dav=(0+d)/2;
54 wav=(56.547+56.547)/2;
55 d01=.524+.56547*.02;
56 w11=0+56.547*0.02;
57 mprintf("d01=% .4 f \nw11=% .5 f ",d01,w11);

```

Chapter 18

LOAD FLOWS

Scilab code Exa 18.1 Determine the voltages at the end of first iteration using gauss seidal method

Determine the voltages at the end of first iteration using gauss seidal method

```
1 //Determine the voltages at the end of first  
iteration using gauss seidal method  
2 clear  
3 clc;  
4 Y=[3-%i*12 -2+%i*8 -1+%i*4 0;-2+%i*8 3.666-%i*14.664  
-.666+%i*2.6664 -1+%i*4;-1+%i*4 -.666+%i*2.6664  
3.666-%i*14.664 -2+%i*8;0 -1+%i*4 -2+%i*8 3-%i  
*12];  
5 P2=-.5;  
6 P3=-.4;  
7 P4=-.3;  
8 Q4=-.1;  
9 Q3=-.3;  
10 Q2=-.2;  
11 V2=1;  
12 V3=1;  
13 V4=1;  
14 V10=1.06;
```

```

15 V30=1;
16 V40=1;
17 V21=((P2-%i*Q2)/V2)-Y(2,1)*V10-Y(2,3)*V30-Y(2,4)*
    V40)/(Y(2,2));
18 V21acc=1+1.6*(V21-1);
19 disp(V21acc,"V21acc=");
20 V31=((P3-%i*Q3)/V3)-Y(3,1)*V10-Y(3,2)*V21acc-Y(3,4)
    *V40)/(Y(3,3));
21 V31acc=1+1.6*(V31-1);
22 disp(V31acc,"V31acc=");
23 V41=((P4-%i*Q4)/V4)-Y(4,2)*V21acc-Y(4,3)*V31acc)/(Y
    (4,4));
24 V41acc=1+1.6*(V41-1);
25 disp(V41acc,"V41acc");

```

Scilab code Exa 18.2 Determine the voltages starting with a flat voltage profile

Determine the voltages starting with a flat voltage profile

```

1 //Determine the voltages starting with a flat
   voltage profile.
2 clear
3 clc;
4
5 Y=[3-%i*12 -2+%i*8 -1+%i*4 0;-2+%i*8 3.666-%i*14.664
   -.666+%i*2.6664 -1+%i*4;-1+%i*4 -.666+%i*2.6664
   3.666-%i*14.664 -2+%i*8;0 -1+%i*4 -2+%i*8 3-%i
   *12];
6 P2=.5;
7 P3=-.4;
8 P4=-.3;
9 Q4=-.1;
10 Q3=-.3;
11 V3=1;

```

```

12 V4=1;
13 V1=1.06;
14 V2=1.04;
15 V30=1;
16 V40=1;
17 Q2=-imag([V2*[Y(2,1)*V1+Y(2,2)*V2+Y(2,3)*V3+Y(2,4)*
    V4]);
18 V21=((P2-%i*Q2)/V2)-Y(2,1)*V1-Y(2,3)*V30-Y(2,4)*V40
    /(Y(2,2));
19 d=atand(0.0291473/1.0472868);
20 V21=1.04*(cosd(d)+%i*sind(d));
21 disp(V21,"V21=");
22 V31=((P3-%i*Q3)/V3)-Y(3,1)*V1-Y(3,2)*V21-Y(3,4)*V40
    /(Y(3,3));
23 disp(V31,"V31=");
24 V41=((P4-%i*Q4)/V4)-Y(4,2)*V21-Y(4,3)*V31)/(Y(4,4))
    ;
25 disp(V41,"V41=");

```

Scilab code Exa 18.3 Solve the previous problem for voltages at the end of first iteration

Solve the previous problem for voltages at the end of first iteration

```

1 // Solve the previous problem for voltages at the
   end of first iteration. for .2<=Q2<=1
2 clear
3 clc;
4
5 Y=[3-%i*12 -2+%i*8 -1+%i*4 0;-2+%i*8 3.666-%i*14.664
   -.666+%i*2.664 -1+%i*4;-1+%i*4 -.666+%i*2.664
   3.666-%i*14.664 -2+%i*8;0 -1+%i*4 -2+%i*8 3-%i
   *12];
6 P2=.5;
7 P3=-.4;

```

```

8 P4=-.3;
9 Q4=-.1;
10 Q3=-.3;
11 V3=1;
12 V4=1;
13 V1=1.06;
14 V2=1;
15 V30=1;
16 V40=1;
17 Q2=.2;
18 V3=1;
19 V21=((P2-%i*Q2)/V2)-Y(2,1)*V1-Y(2,3)*V30-Y(2,4)*V40
      /(Y(2,2));
20 V31=((P3-%i*Q3)/V3)-Y(3,1)*V1-Y(3,2)*V21-Y(3,4)*V40
      /(Y(3,3));
21 V41=((P4-%i*Q4)/V4)-Y(4,2)*V21-Y(4,3)*V31/(Y(4,4))
      ;
22 disp(V21,"V21=");
23 disp(V31,"V31=");
24 disp(V41,"V41=");

```

Scilab code Exa 18.4 Determine the set of load flow equations at the end of first iteration by using Newton Raphson method

Determine the set of load flow equations at the end of first iteration by using Ne

```

1 //Determine the set of load flow equations at the
   end of first iteration by using Newton Raphson
   method .
2 clear
3 clc;
4 Y=[6.25-%i*18.75 -1.25+%i*3.75 -5+%i*15;-1.25+%i
   *3.75 2.916-%i*8.75 -1.666+%i*5;-5+%i*15 -1.666+
   %i*5 6.666-%i*20];
5 V1=1.06;
```

```

6 G11=6.25;
7 G12=-1.25;
8 G21=G12;
9 G13=-5;
10 G31=G13;
11 G22=2.916;
12 G23=-1.666;
13 G32=G23;
14 G33=6.666;
15 B11=18.75;
16 B12=-3.75;
17 B21=B12;
18 B13=-15;
19 B31=B13;
20 B22=8.75;
21 B23=-5;
22 B32=B23;
23 B33=20;
24 e1=1.06;
25 e2=1;
26 e3=1;
27 f1=0;
28 f2=0;
29 f3=0;
30 P2=e2*(e1*G21+f1*B21) +f2*(f1*G21-e1*B21) +e2*(e2*
   G22+f2*B22)+f2*(f2*G22-e2*B22)+e2*(e3*G23+f3*B23)
   +f2*(f3*G23-e3*B23);
31 P3=-.3
32 Q2=-.225;
33 Q3=-.9;
34 dP2=.2-(-.225);
35 dP3=-.6-(-.3);
36 dQ2=0-(-.225);
37 dQ3=-.25-(-.9);
38 a1=2*e2*G22+e1*G21+f1*B21+e3*G23+f3*B23; // a1=dP2/de2
39 a2=2*e3*G33+e1*G31+f1*B31+e3*G32+f2*B32; // a2=dP3/de3
40 b1=2*f2*G22 +f1*G21-e1*B21+f3*G23-e3*B23; // b1=dP2/
   df2

```

```

41 b2=20.9; //dP3/df3
42 a3=e2*G23-f2*B23; //dP2/de3
43 a4=-1.666; //dP3/de2
44 b3=-5; //dP2/df3
45 b4=-5; //dP3/df2
46 c1=2*e2*B22-f1*G21+e1*B21-f3*G23+e3*B23; //dQ2/de2
47 c2=19.1; //dQ3/de3
48 c3=-2.991; //dQ2/df2
49 c4=-6.966; //dQ3/df3
50 mprintf("set of linear equations at the end of first
           iteration are\n");
51 mprintf("%.3 fde2 %.3 fde3+ %.3 fdf2 %.3 fdf3 = %.3 f\n"
           ,2.846,-1.666,8.975,-5,2.75);
52 mprintf("%.3 fde2 +%.3 fde3 %.3 fdf2 +%.3 fdf3 = %.3 f\n"
           ,-1.666,6.366,-5,20.90,-.3);
53 mprintf("%.3 fde2 %.3 fde3 %.3 fdf2 +%.3 fdf3 = %.3 f\n"
           ,8.525,-5,-2.991,1.666,.225);
54 mprintf("%.3 fde2 +%.3 fde3+ %.3 fdf2 %.3 fdf3 = %.3 f\n"
           ,-5,19.1,1.666,-6.966,.65);

```

Scilab code Exa 18.5 Determine the equations at the end of first iteration after applying given constraints

Determine the equations at the end of first iteration after applying given constraints

```

1 //Determine the equations at the end of first
   iteration after applying given constraints.
2 clear
3 clc;
4 Q2=-.225;
5 dP2=.2-(-.075);
6 dP3=-.6-(-.3);
7 dQ3=-.25-(-.9);
8 dV2=1.04^2 - 1^2; //dV2=|dV2|^2

```

```
9 mprintf("set of linear equations at the end of first
iteration are\n");
10 mprintf("%.3 fde2 %.3 fde3+ %.3 fdf2 %.3 fdf3 = %.3 f\n"
,2.846,-1.666,8.975,-5,2.75);
11 mprintf("%.3 fde2 +%.3 fde3 %.3 fdf2 +%.3 fdf3 = %.3 f\n"
,-1.666,6.366,-5,20.90,-.3);
12 mprintf("%.3 fde2 %.3 fde3 %.3 fdf2 +%.3 fdf3 = %.3 f\n"
,8.525,-5,-2.991,1.666,.225);
13 mprintf("%.3 fde2 +%.3 fde3+ %.3 fdf2 +%.3 fdf3 = %.5 f\n"
,2,0,0,0,dV2);
```

Chapter 19

ECONOMIC LOAD DISPATCH

Scilab code Exa 19.1 To Determine the economic operating schedule and the corresponding cost of generation b Determine the savings obtained by loading the units

To Determine the economic operating schedule and the corresponding cost of generation

```
1 // To Determine the economic operating schedule and
   the corresponding cost of generation.(b)Determine
   the savings obtained by loading the units.
2 clear
3 clc;
4 //dF1/dP1=.4*P1+40 per MWhr
5 //dF2/dP2=.5*P1+30 per MWhr
6 mprintf("two equations are :\n");
7 mprintf("%.1 f P1 %.1 f P2 = %.1 f\n" , .4 , - .5 , -10);
8 mprintf("%.1 f P1+ %.1 f P2 = %.1 f\n" , 1 , 1 , 180);
9 A=[.4 - .5;1 1];
10 B=[-10;180];
11 P=(inv(A))*B;
12 P1=P(1,1);
13 P2=P(2,1);
```

```

14 F1=.2*(P1)^2 +40*P1+120;
15 F2=.25*(P2)^2+30*P2+150;
16 Total=F1+F2; //Total cost
17 mprintf("(a) Cost of Generation=Rs %.2f /hr\n",Total)
    ;
18 P1=90;
19 P2=90;
20 F1=.2*(P1)^2 +40*P1+120;
21 F2=.25*(P2)^2+30*P2+150;
22 Total2=F1+F2; //Total cost
23 savings=Total2-Total
24 mprintf("(b) Savings=Rs %.2f /hr\n",savings)

```

Scilab code Exa 19.2 Determine the incremental cost of received power and penalty factor of the plant

Determine the incremental cost of received power and penalty factor of the plant

```

1 //Determine the incremental cost of received power
   and penalty factor of the plant
2 clear
3 clc;
4 pf=10/8;//penalty factor
5 cost=(.1*10+3)*pf;//Cost of received power=dF1/dP1
6 mprintf("Penalty Factor=%f\n",pf);
7 mprintf("Cost of received Power=Rs %f /MWhr",cost)
    ;

```

Scilab code Exa 19.4 Determine the minimum cost of generation

Determine the minimum cost of generation

```

1 //Determine the minimum cost of generation .
2 clear
3 clc;
4 //dF1/dP1=.048*P1+8
5 //dF2/dP2=.08*P1+6
6 mprintf("two equations are :\n");
7 mprintf("%.3 f P1 %.2 f P2 = %.1 f\n" , .048 , -.08 , -2);
8 mprintf("%.1 f P1+ %.1 f P2 = %.1 f\n" , 1 , 1 , 50);
9 A=[.048 -.08;1 1];
10 B=[-2;50];
11 P=(inv(A))*B;
12 P1=P(1,1);
13 P2=P(2,1);
14 F1=(.024*(P1)^2 +8*P1+80)*(10^6);
15 F2=(.04*(P2)^2+6*P2+120)*(10^6);
16 mprintf("when load is 150MW , equations are: :\n");
17 mprintf("%.3 f P1 %.2 f P2 = %.1 f\n" , .048 , -.08 , -2);
18 mprintf("%.1 f P1+ %.1 f P2 = %.1 f\n" , 1 , 1 , 150);
19 A=[.048 -.08;1 1];
20 B=[-2;150];
21 P=(inv(A))*B;
22 P1=P(1,1);
23 P2=P(2,1);
24 f1=(.024*(P1)^2 +8*P1+80)*(10^6);
25 f2=(.04*(P2)^2+6*P2+120)*(10^6);
26 Total=(F1+F2+f1+f2)*12*2/(10^6);
27 mprintf("Total cost=Rs. %.2 f" , Total)

```

Chapter 20

LOAD FREQUENCY CONTROL

Scilab code Exa 20.1 Determine the load taken by the set C and indicate the direction in which the energy is flowing

Determine the load taken by the set C and indicate the direction in which the ene

```
1 //Determine the load taken by the set C and indicate
   the direction in which the energy is flowing
2 clear
3 clc;
4 //let x MW flows from A to B
5 //Load on station A=75+x
6 //drop in speed =5*(75+x)/200
7 //load on station B =(30-x)
8 //drp in speed=(30-x)*4/75
9 x=(1.6-1.875)/(.025+.12+.0533); //by manipulating
   equation : 5*(75+x)/200 + 3*x/25 =(30-x)*4/75
10 mprintf("x=% .2 f MW\n",x);
11 mprintf("which means power of magnitude % .2 f MW will
   be from B to A",abs(x));
```

Scilab code Exa 20.2 Determine the load shared by each machine

Determine the load shared by each machine

```
1 // Determine the load shared by each machine .
2 clear
3 clc;
4 //Let x be the power supplied by 110 MW unit
5 // the percent drop in speed = 5x/110
6 x=(250*11)/(21+11); // by manipulating equation : 5x
//110=5x(250-x)/210
7 P=250-x; //Power shared by 210 MW unit
8 mprintf("Power supplied by 210 MW unit = %.2f MW \n"
,P);
```

Scilab code Exa 20.3 Determine the frequency to which the generated voltage drops before the steam flow commences to increase to meet the new load

Determine the frequency to which the generated voltage drops before the steam flow

```
1 // Determine the frequency to which the generated
voltage drops before the steam flow commences to
increase to meet the new load
2 clear
3 clc;
4 E=4.5*100; //Energy stored at no load (MJ)
5 E1=25*.6; //Energy lost by rotor (MJ)
6 fnew=sqrt((E-E1)/E)*50;
7 mprintf("new frequency will be %.2f Hz" ,fnew);
```

Chapter 21

COMPENSATION IN POWER SYSTEMS

Scilab code Exa 21.1 Determine the load bus voltage

Determine the load bus voltage

```
1 //Determine the load bus voltage
2 clear
3 clc;
4 load1=10+%i*15; //load per phase(MVA)
5 SCC=250/3;
6 V=11/ sqrt(3);
7 P=30;
8 Q=45;
9 Z=(11/ sqrt(3))^2/(250/3); //Equivalent short circuit
      impedance
10 dsc=atand(5);
11 R=.0949;
12 X=.4746;
13 //Using equation: V^2= (Vcosd+PR/V)^2 + (Vsind+QX/V)
      ^2, we get
14 y=poly([51.7 0 -27.5 0 1], 'V', 'c');
15 disp(y,"we get equation :");
```

```
16 X=roots(y);
17 disp(X,"Roots of above equation are ");
18 V=5.046;
19 mprintf("V=%f\n",V);
20 dV=6.35-V;
21 Ssc=250;
22 // using expression ,a=dV/v=1(Pcos(dsc)+Qsin(dsc))/Ssc
   +j(Psin(dsc)-Qcos(dsc))/Ssc
23 a=(P*cosd(dsc)+Q*sind(dsc))/Ssc +%i*(P*sind(dsc)-Q*
   cosd(dsc))/Ssc;
24 disp(abs(a),"dV/V= ");
```

Chapter 22

POWER SYSTEM VOLTAGE STABILITY

Scilab code Exa 22.2 To Determine the source voltage when the load is disconnected to load pf i unity ii 8 lag

To Determine the source voltage when the load is disconnected to load pf i unity ii 8 lag

```
1 // To Determine the source voltage when the load is
   disconnected to load p.f (i) unity (ii).8 lag.
2 clear
3 clc;
4 Vb=500;
5 Sb=1000;
6 Zb=Vb^2/Sb;
7 Xpu=.35*100/Zb;
8 Zth=1000/5000;
9 X=Xpu+Zth;
10 V=1;
11 Q=0;
12 P=1;
13 Eth=V+(Q*X/V)+%i*(P*X/V);
14 Q=.75;
15 Eth1=V+(Q*X/V)+%i*(P*X/V);
```

```
16 printf("( i ) For p.f unity , Eth=%f V" ,Eth);  
17 disp(Eth1,"( i ) For p.f .8 , Eth=");
```

Scilab code Exa 22.3 To determine thee Ac system voltage when the dc system is disconnected or shutdown

To determine thee Ac system voltage when the dc system is disconnected or shutdown

```
1 // To determine thee Ac system voltage when the dc  
    system is disconnected or shutdown  
2 clear  
3 clc;  
4  
5 X=.625;  
6 P=1;  
7 Q=.6;  
8 V=1;  
9 Eth=V+(Q*X/V)+%i*(P*X/V);  
10 Phase_Eth=atand(imag(Eth)/real(Eth));  
11 mprintf("Eth=%f at an angle %f degrees",abs(Eth)  
    ,Phase_Eth);
```

Scilab code Exa 22.4 To Calculate the new on and off times for constant energy

To Calculate the new on and off times for constant energy

```
1 // To Calculate the new on and off times for  
    constant energy.  
2 clear  
3 clc;  
4
```

```
5 P=.5;
6 toff=4;
7 ton=(P*töff-0*töff)/(.8-P);
8 mprintf("töff= 4min.\n")
9 mprintf("ton(min.)=%f min.\n",ton);
```

Scilab code Exa 22.6 To discuss the effect of tap changing

To discuss the effect of tap changing

```
1 // To discuss the effect of tap changing
2 clear
3 clc;
4 V=1;
5 Qload=1*V
6 Qcap=-.75*V^2;
7 Qnet=Qload+Qcap;
8 VS=1-.75*2*V; // voltage sensitivity
9 mprintf("Voltage sensitivity=%f\n",VS);
10 mprintf("since the voltage sensitivity is negative
,\\n voltage regulation by tap changing will
reduce net reactive load and improve voltage
stability ");
```

Scilab code Exa 22.7 To determine the effect of tapping to raise the secondary voltage by 10percent

To determine the effect of tapping to raise the secondary voltage by 10percent

```
1 //To determine the effect of tapping to raise the
secondary voltage by 10%
2 clear
```

```

3 clc;
4
5 Y=-%i*10;
6 n=1+.1;
7 Y1=n*(n-1)*Y;
8 Y2=(1-n)*Y;
9 disp(Y1,"Y1=");
10 disp(Y2,"Y2=");
11 disp("The shunt elements equal to a reactor of 1.1V1
      ^2 size oin the primary side and a capacitive of
      sixe 1V2^2 on the secondary side");

```

Scilab code Exa 22.8 Calculate the additional reactive power capability at full load

Calculate the additional reactive power capability at full load

```

1 //Calculate the additional reactive power capability
   at full load
2 clear;
3 clc;
4 P=1; //assuming
5 S1=P/.95; //For pf .95
6 S2=P/.8; //For pf .8
7 dMVA=(S2-S1)*100/P; //Increase in MVA rating
8 Q1=P*tand(acosd(.95)); //Q for pf .95
9 Q2=P*tand(acosd(.8)); //Q for pf .8
10 dPc=(Q2-Q1)*100/Q1 //Percent additional Reactive
      Power Capability
11 mprintf("Percent additional Reactive Power
      Capability is %.0f",dPc)

```

Chapter 23

STATE ESTIMATION IN POWER SYSTEMS

Scilab code Exa 23.1 To determine the state vector at the end of first iteration

To determine the state vector at the end of first iteration

```
1 // To determine the state vector at the end of first
   iteration
2 clear
3 clc;
4 C1=.02*100;
5 C2=.05;
6 Fs=100;
7 S1=.41 -%i*.11;
8 S2=-.4 +%i*.10;
9 S3=-.105 +%i*.11;
10 S4=-.105 +%i*.11;
11 S5=.14 -%i*.14;
12 S6=-.7 +%i*.35;
13 Z12=.08+%i*.24;
14 Z23=.06+%i*.18;
15 Z31=.02+%i*.06;
```

```

16 Z21=Z12 ;
17 Z32=Z23 ;
18 Z13=Z31 ;
19 W1=(50*10^(-6))/((C1*abs(S1)+(C2*(Fs)))^2) ;
20 W2=(50*10^(-6))/((C1*abs(S2)+C2*(Fs))^2) ;
21 W3=(50*10^(-6))/((C1*abs(S3)+C2*(Fs))^2) ;
22 W4=(50*10^(-6))/((C1*abs(S4)+C2*(Fs))^2) ;
23 W5=(50*10^(-6))/((C1*abs(S5)+C2*(Fs))^2) ;
24 W6=(50*10^(-6))/((C1*abs(S6)+C2*(Fs))^2) ;
25 disp(W1,"W1="); // Answers for W1,W2,W3,W4,W5,W6 in
                     the book is wrongly Calculated
26 disp(W2,"W2=");
27 disp(W3,"W3=");
28 disp(W4,"W4=");
29 disp(W5,"W5=");
30 disp(W6,"W6=");
31 a1=W1/(abs(13)^2)
32 [D]=diag([W1/(abs(Z13)^2);W2/(abs(Z31)^2);W3/(abs(
           Z12)^2);W4/(abs(Z21)^2);W5/(abs(Z23)^2);W6/(abs(
           Z32)^2)]);
33 A=[-1 0 1;1 0 -1;1 -1 0;-1 1 0;0 1 -1;0 -1 1];
34 B=[-1 0;1 0;1 -1;-1 1;0 1;0 -1];
35 b=[1;-1;0;0;-1;1];
36 C=(B')*D; // Assuming Transpose(B)*D=C
37 F=(B')*D*B; // Assuming Transpose(B)*D*B=F
38 G=(inv(F))*C; // Assuming (BTDB)^-1*(BT)*D=F
39 E1=1.05;
40 E2=E1;
41 E3=E1;
42 invH=diag([Z31/E3;Z13/E1;Z12/E1;Z21/E2;Z23/E2;Z32/E2
            ]);
43 Sm=[.41+%i*.11;-.4-%i*.1;-.105-%i*.11;.14+%
      *.14;.72+%i*.37;-.7+%
      %i*.35];
44 EMo=invH*Sm;
45 a=EMo-b*E1;
46 E=G*a;
47 disp(E,"E="); // Answers differs due to wrong
                     calculation of W1,W2,W3,W4,W5,W6

```

Scilab code Exa 23.2 Determine The States of the systems at the end of first iteration

Determine The States of the systems at the end of first iteration

```
1 // Determine The States of the systems at the end of
   first iteration.
2 clear
3 clc
4 Qm1=-.24;
5 Qm2=-.24;
6 Qm3=.5;
7 do=0;
8 Pm1=.12;
9 Pm2=.21;
10 Pm3=-.30;
11 W1=3;
12 r1=W1; //assuming r1=Inverse (R1)
13 W2=5;
14 r2=W2; //assuming r2=Inverse (R1)
15 W3=2;
16 r3=W3; //assuming r3=Inverse (R1)
17 X12=%i*.03;
18 X13=%i*.01;
19 X23=%i*.02;
20 X21=X12;
21 X31=X13;
22 X32=X23;
23 Vo=[1.05;1.05];
24 H=[-1/.03 -1/.01;((1/.03)+(1/.02)) -1/.02;-1/.02
      ((1/.01)+1/.02)]; //assuming dh/dl=H
25 A1=[3327+34700+5000 9990-20825-15000; -25835
      30000+12500+45000];
26 V=Vo+inv(A1)*(H')*(diag([W1;W2;W3]))*[Qm1;Qm2;Qm3];
```

```
27 d=do+inv(A1)*(H')*(diag([W1;W2;W3]))*[Pm1;Pm2;Pm3];  
    //assuming d=dell matrix and do=intial matrix=0  
28 disp(V,"V=");  
29 disp(d,"d=");
```

Scilab code Exa 23.3 Problem on State Estimator Linear Model

Problem on State Estimator Linear Model

```
1 //Problem on State Estimator Linear Model  
2  
3 clear  
4 clc;  
5 A=[-3.33 0;0 10;5 -5];  
6 R=[10^-4 0 0;0 10^-4 0;0 0 10^-4];  
7 O=inv(((A')*(inv(R))*(A)))*((A')*(inv(R))  
    * [.12; .21; -.30]); //assuming theat matrix=0  
8 f12=-3.33*(O(1,1));  
9 f31=10*(O(2,1));  
10 f23=5*(O(1,1)-O(2,1));  
11 J=(((.12-f12)^2)+((.21-f31)^2)+((-3-f23)^2))  
    /(10^-4);  
12 disp(O,"O="); //Answer does not match due to  
    difference in rounding off of digits  
13 disp(J,"J="); //Answer does not match due to  
    difference in rounding off of digits
```

Scilab code Exa 23.4 Determine theta1 Theta2

Determine theta1 Theta2

```

1 //Determine theta1 Theta2
2 clear
3 clc;
4 A=[5 -5;2.5 0;4 -4];
5 R=[10^-4 0 0;0 10^-4 0;0 0 10^-4];
6 O=inv(((A')*(inv(R))*(A)))*((A')*(inv(R)))
    * [.60;.05;.35]); //assuming theat matrix=0
7 f12=5*(O(1,1)-O(2,1));
8 f13=2.5*(O(1,1));
9 f32=-4*(O(2,1));
10 J=(((.6-f12)^2)+((.05-f13)^2)+((.35-f32)^2))/(10^-4)
    ;
11 //Answer does not match due to difference in
    rounding off of digits
12 disp(O(1,1),"Theta1=");
13 disp(O(2,1),"Theta2=");

```

Chapter 24

UNIT COMMITMENT

Scilab code Exa 24.3 Priority List Method

Priority List Method

```
1 // Priority List Method
2 clear
3 clc;
4 Fc1=1.1; //Fuel cost (1)=Rs 1.1/MBtu
5 Fc2=1; //Fuel cost (2)=1/MBtu
6 Fc3=1.2; //Fuel cost (3)=1.2/MBtu
7 P1max=600;
8 P1=P1max;
9 F1=600+7.1*P1+0.00141*(P1^2); //For P1= Pm1ax
10 Favg1=F1*Fc1/600; //Full load average production cost
11 P2max=450;
12 P2=P2max;
13 F2=350+7.8*P2+0.00195*(P2^2); //For P2= P2max
14 Favg2=F2*Fc2/450; //Full load average production cost
15 P3max=250;
16 P3=P3max;
17 F3=80+8*P3+0.0049*(P3^2); //For P3= P3max
18 Favg3=F3*Fc3/250; //Full load average production cost
19 mprintf(" Priority List is as follows\n");
```

```

20 mprintf(" Unit          Rs/MWhr      MinMW      Max MW\
n")
21 mprintf(" 2          %.3 f      100        %.0 f
\ n", Favg2 , P2max)
22 mprintf(" 1          %.4 f      60         %.0 f
\ n", Favg1 , P1max)
23 mprintf(" 3          %.2 f      50         %.0 f
\ n\ n", Favg3 , P3max)
24 Fmax1=P1max+P2max+P3max;
25 Fmax2=P2max+P1max
26 Fmax3=P2max
27 mprintf(" Unit Commitment Scheme is follows \n")
28 mprintf(" Combination      Min.MW from Combination
           Max.MW from Combination\n");
29 mprintf("2+1+3          310
           %.0 f      \ n", Fmax1);
30 mprintf("2+1          260
           %.0 f      \ n", Fmax2);
31 mprintf("2          100
           %.0 f      " , Fmax3);

```

Scilab code Exa 24.4 illustrate the dynamic programming for preparing an optimal unit commitment

illustrate the dynamic programming for preparing an optimal unit commitment

```

1 // illustrate the dynamic programming for preparing
   an optimal unit commitment.
2
3 clear
4 clc;
5 function [F1]=F1(P1)
6     F1=7.1*P1+.00141*(P1^2)
7     mprintf("F1(% .0 f )=% .1 f \ n" ,P1 ,F1);
8 endfunction

```

```

9  function [f2]=f2(P2)
10     f2=7.8*P2+.00195*(P2^2)
11     mprintf(" f2 (%.0f )=% .0f \n" ,P2 ,f2) ;
12 endfunction
13 function [F]=F(P1 ,P2)
14     F1=7.1*P1+.00141*(P1^2)
15     F2=7.8*P2+.00195*(P2^2)
16     F=F1+F2
17     mprintf(" F1(% .0f )+f2 (%.0f )=% .0f \n" ,P1 ,P2 ,F) ;
18 endfunction
19 P1max=600;
20 P2max=450;
21 mprintf(" Unit Commitment using Load 500MW\n")
22 F1(500);
23 mprintf(" Since min. Power of second unit is 100MW ,
we find \n");
24 F(400,100);
25 F(380,120);
26 F(360,140);
27 mprintf(" Therefore for load 500 MW , the load
commitment on unit 1 is 400 MW and that on 2 is
100 MW which gives min. cost\n");
28 mprintf(" Next we increase the load by 50 MW and
loading unit 1 we get , \n");
29 F1(550);
30 mprintf(" Also if we distribute a part of load to
unit 2 we get ,\n")
31 F(450,100);
32 F(400,150);
33 F(350,200);
34 mprintf(" Therefore for load 550 MW , the load
commitment on unit 1 is 400 MW and that on 2 is
150 MW which gives min. cost\n");

```

Chapter 25

ECONOMIC SCHEDULING OF HYDROTHERMAL PLANTS AND OPTIMAL POWER FLOWS

Scilab code Exa 25.1 illustrating the procedure for economic scheduling
clear all

illustrating the procedure for economic scheduling clear all

```
1 // illustrating the procedure for economic
   scheduling
2 clear
3 clc;
4 q2=25;
5 q3=25
6 q1=70-(q2+q3);
7 Wo=120;
8 W3=50;
9 Wi1=0;
10 Wi2=0;
11 W1=Wo+Wi1-q1;
```

```

12 W2=W1+Wi2-q2
13 PH1=9.81*(10^-3)*20*[1+(.5*.006*(120+100))]*(20-2);
14 PH2=9.81*(10^-3)*20*[1+(.5*.006*(100+75))]*(23); //
    Answer in the book is not Correct due to wrong
    calculation
15 PH3=9.81*(10^-3)*20*[1+(.5*.006*(75+50))]*(23);
16 PT1=8-PH1;
17 PT2=12-PH2;
18 PT3=7-PH3;
19 L11=20+PT1; //dFT/dPT=PT+20
20 L12=20+PT2; //dF/dp=PT+20
21 L13=20+PT3; //dF/dp=PT+20
22 //dPL/dPH=0
23 L31=L11;
24 L32=L12;
25 L33=L13;
26 e=.006;
27 ho=.1962
28 Rho=2;
29 L21=L31*ho*[1+(.5*e*(2*Wo+Wi1-2*q1+Rho))]
30 L22=L21-L31*[.5*ho*e*(q1-Rho)]-L32*[.5*ho*e*(q2-Rho)
    ] //for m=1
31 L23=L22-L32*[.5*ho*e*(q2-Rho)]-L33*[.5*ho*e*(q3-Rho)
    ] //for m=2
32 G1=L22-L32*ho*[1+.5*.006*(2*100-2*25+2)] //G1=dF/dq2
    Answer doent match due to wrong calculation of
    PH2 in a book;
33 G2=L23-L33*ho*[1+.5*.006*(2*W2+0-2*q3+Rho)] //G1=dF/
    dq3;
34 a=0.4;
35 qnew2=q2-a*G1; // Answer differs due to wrong
    calculation of PH2 in the book
36 qnew3=q3-a*G2;
37 q1=120-50-(qnew2+qnew3);
38 mprintf(" Let q2=%f q3=%f q1=%f\n" ,q2,q3,
    q1);
39 mprintf("W1=%f W2=%f\n" ,W1,W2);
40 mprintf("PH1=%f PH2=%f PH3=%f\n" ,PH1,
    PH2,PH3);

```

```

    PH2 , PH3) ;
41 mprintf("Thermal generation during Three Intervals \
n PT1=% .2 f      PT2=% .2 f      PT3=% .1 f\n" ,PT1 ,PT2 ,
PT3) ;
42 mprintf("Value of L1 for the three intervals , \n L11
= % .2 f      L12=% .2 f      L13=% .1 f\n" ,L11 ,L12 ,L13) ;
43 mprintf("Neglecting transmission losses we get\n L11
=L31      L12=L32      L13=L33\n") ;
44 mprintf("L21=% .3 f\n" ,L21)
45 mprintf("For m=1 and 2 we get \n L22=% .1 f \n L23=% .1
f\n" ,L22 ,L23) ;
46 mprintf("Gradient Vectors \n dF/dq2=% .2 f\n dF/dq3=%
.1 f\n" ,G1 ,G2)
47 mprintf("q2new=% .3 f \n q3new=% .1 f\n q1=% .0 f" ,qnew2 ,
qnew3 ,q1)

```
